

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 7/2/02

5:50:00 PM

ATC Group #: 8382

Analysis Date: 7/3/02

Project: NYC-DEP W & P File # 1079.01.02

47 Ann Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
JB70202-9 8382 -1	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046
JB70202-1 8382 -2	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046
JB70202-1 8382 -3	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046
JB70202-1 8382 -4	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046
JB70202-1 8382 -5	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101167-0, NY State ELAP #10879

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0030

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1
P.O.

CONTACT: Mike Nolan

W&P FILE #: 1079-91.92

LABORATORY: R TC

ANALYSIS METHOD: PCM TEM TEM
circle one AHERA EPA LEVEL II

CLIENT: NYCOEP
PROJECT: 479 Ave ST
LOCATION: Roof

TECHNICIAN:

8382

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE		TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTRATION (fib/cc.)
				START	STOP					
JB70202-9	inside roof door	TEM		10	10	1415	1643	150	1500	
JB70202-10	North side roof	TEM		10	10	1417	1647	150	1500	
JB70202-11	South side roof	TEM		10	10	1418	1649	150	1500	
JB70202-12	West side roof	TEM		10	10	1421	1651	150	1500	
JB70202-13	East side roof	TEM		10	10	1423	1651	150	1500	
JB70202-14	Field Blank	NA		NA	NA	0	0	0	0	
JB70202-15	"	NA		NA	NA	0	0	0	0	
JB70202-16	Sealed Blank	NA		NA	NA	0	0	0	0	

COMMENTS:

SAMPLE BY: John Boyd
SIGNATURE: [Signature]
RELEASED BY: John Boyd
SIGNATURE: [Signature]
RECEIVED BY: [Signature]
SIGNATURE: [Signature]

DATE: 7.2.02
DATE: 7.2.02
DATE: 7.2.02
DATE: 7.2.02

SAMPLE TYPE CODES			
1 - Blank	5 - Final Clearance (inside)	7 - Personal	8 - Background
2 - Pre-Abatement	6 - Final Clearance (outside)		
3 - During Abatement			
4 - During Glove Bag Removal			

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8382

Date: Wednesday, July 03, 2002

Client Project: NYC-DEP W & P File # 1079.01.02
47 Ann Street

Time: 2:40:31 PM

Comments:

Number of Pages: 3
(including cover page)