

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01 02
44 / 46 / 48 Ann Street

Received: 6/24/02 7:00:00 AM

ATC Group #: 8253

Analysis Date: 6/24/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³) (S/cc)	Notes
41 8253 -1	1200.00	0.0674	0	None Detected	0	0.0048	<14.83 <0.0048	
42 8253 -2	1800.00	0.0450	0	None Detected	0	0.0048	<22.24 <0.0048	
43 8253 -3	1800.00	0.0450	0	None Detected	0	0.0048	<22.24 <0.0048	
44 8253 -4	1800.00	0.0450	0	CHRYSTILE	0	0.0048	22.24 0.0048	
45 8253 -5	1800.00	0.0430	0	None Detected	0	0.0048	<22.24 <0.0048	
49 8253 -6	1680.00	0.0562	0	None Detected	0	0.0041	<17.79 <0.0041	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PL/TEM #101157-0, NY State ELAP #10370

228 East 45th Street
New York, NY 10017
(212) 922-8077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O.

CLIENT: NYC-DEP

W&P FILE #: 1079.01.07

PROJECT: Power Cleaning

LABORATORY: ATC

CONTACT: NELSON

LOCATION: 44/46/48 Ave Str

ANALYSIS METHOD: PCM

TEM

EPA LEVEL II

circle one

TECHNICIAN: FAYED EL-GHUNDI

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE		TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
				START	STOP					
41	By THE Building # 42	3		5	5	1026	1426	240	1200	
42	By THE Building # 44					1027	1627	360	1800	
43	" " " # 46					1028	1628	360	1800	
44	" " " # 48					1029	1629	360	1800	
45	" " " DECK					1030	1630	360	1800	
46	F. BLANK	3		5	5					
47	" "									
48	" "									
49	By THE Building # 42	3		8	8	1426	1756	210	1680	

COMMENTS:

SAMPLE BY:	FAYED EL-GHUNDI	DATE:	6.23.02
SIGNATURE:	F. Ghund		
RELEASED BY:	ATC	DATE:	6.23.02
SIGNATURE:	ATC		
RECEIVED BY:	ATC	DATE:	6.24/02
SIGNATURE:	ATC		

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8253

Date: Monday, June 24, 2002

Client Project: NYC-DEP W & P File # 1073.01.02
44 / 46 / 48 Ann Street

Time: 12:01:26 PM

Number of Pages:

3
(including cover page)

Comments: