

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306

**Attn:** Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630**Phone:** (212) 922-0077**Received:** 6/25/02

6:00:00 PM

ATC Group #: 8285**Analysis Date:** 6/26/02**Project:** NYC-DEP W & P File #: 1079.01.02

119 Fulton Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
03 8285 -1	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049
04 8285 -2	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049
05 8285 -3	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049
06 8285 -4	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049
07 8285 -5	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879

9

Page 1 of 1

Sample	Volume	Analyzed	Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Sensitivity (S/cc)	Concentration (S/mm ²)	(S/cc)	Notes
03 8285 -1	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049
04 8285 -2	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049
05 8285 -3	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049
06 8285 -4	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049
07 8285 -5	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 1



WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE _____ OF _____

04

P.O.

W&P FILE #: 1079-01-02

CLIENT: MYC DEP

LABORATORY: ATC

PROJECT: 119 FULSON PT - RACK COW

LOCATION: ANNA FACADE

LABORATORY: ATC

ANALYSIS METHOD: PCM ~~TEM~~ TEM

CONTACT:

#A177

SCA JOB#:

TECHNICIAN: festi gennipens

TECHNICIAN: TERRY CHAMBERLAIN											
SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOW RATE		ON	TIME		TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
				START	STOP		OFF				
01	BLANK	1									
02	BLANK	1									
03	AROUND W/ A SIDE 1	3		5	5	0830	1420	350	1750		
04		3		5	5	0832	1423	350	1750		
05		3		5	5	0834	1424	350	1750		
06		3		5	5	0836	1426	350	1750		
07	AROUND W/ A SIDE 5	3		5	5	0838	1428	350	1750		

COMMENTS:

SAMPLE BY: F3817 DiemwE Gr DATE: 04-25-09

SIGNATURE: _____

RELEASED BY: 128710 DATE: 1-25-67

SIGNATURE: _____

RECEIVED BY: _____ DATE: _____

SIGNATURE: _____

DATE: _____

SAMPLE TYPE CODES

1 - Blank

2 - Pre-Abatement

3 - During Abatement

4 - During Glove Bag Removal

5 - Final Clearance (inside)

6. Final Clearance (outside)

7. Personal

8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

ATC Group #: 8285

Fax #: (212) 922-0630

Client Project: NYC-DEP W & P File #: 1079.01.02
119 Fulton Street

Date: Wednesday, June 26, 2002

Time: 1:56:12 AM

Comments:

Number of Pages: 3
(including cover page)

7