

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Received: 7/1/02 8:00:00 AM
 ATC Group #: 8361
 Analysis Date: 7/1/02

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02
 110 Chamber Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8361 -1	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
02 8361 -2	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
03 8361 -3	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
04 8361 -4	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
05 8361 -5	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879

228 East 45th Street
New York, NY 10017
(212) 922-8077
Fax (212) 922-4630

WARREN & PANZER ENGINEERS, P.C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

W&P FILE #: 1079-01-02

CLIENT: NYC DEP

PROJECT: 110 Chambers St

LOCATION: ~~BRIDGE~~

LABORATORY: ATC

ANALYSIS METHOD: PCM TEM
circle one AHERA EPA LEVEL 1

TECHNICIAN: R. FERNANDEZ

8361

CONTACT:

9

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (mg./cc.)
01	Thermostat East TC	3		8.0	8.0	1241	1541	180	1440	
02	(C) SIDE OF BLDG (Front)	3		8.0	8.0	1242	1542			
03	MIDDLE OF BLDG (RIPED)	3		8.0	8.0	1244	1544			
04	TRUCK MIDDLE	3		8.0	8.0	1245	1545			
05	TELEPHONE Booth NYC PL.	3		8.0	8.0	1248	1548	180	1440	
06	FB	1								
07	FB	1								

COMMENTS:

SAMPLE BY: R. FERNANDEZ	DATE: 6/24/11
SIGNATURE:	
RELEASED BY:	DATE:
SIGNATURE:	
RECEIVED BY: ATC	DATE: 7/14/12
SIGNATURE:	Sam

SAMPLE TYPE CODES

1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PRYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8361

Date: Monday, July 01, 2002

Client Project: NYC-DEP W & P File #: 1079.01.02
110 Chamber Street

Time: 1:12:33 PM

Number of Pages:

3

(including cover page)

Comments:

4