

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 7/1/02

8:00:00 AM

ATC Group #: 8361

Analysis Date: 7/1/02

Project: NYC-DEP W & P File #: 1079.01.02

110 Chamber Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5 µm	5µ		(S/mm ³)	(S/cc)	
01 8361 -1	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
02 8361 -2	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
03 8361 -3	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
04 8361 -4	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
05 8361 -5	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

(24 hr⁺/a)

W&P FILE #: 1079-01-02

CLIENT: NYC DEP

PROJECT: 110 CHAMBER ST

LOCATION: FRODO

LABORATORY: ATC

ANALYSIS METHOD: PCM

circle one

TECHNICIAN: R. FRAVANDI

CONTACT:

TEM

AHERA

EPA LEVEL II

8361

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (mg/cc)
01	THROUGH BOOTH	3		8.0	8.0	1241	1541	180	1440	
02	(1) SIDE OF BLDG (Front)	3		8.0	8.0	1242	1542			
03	MIDDLE OF BLDG (FRONT)	3		8.0	8.0	1244	1544			
04	TRUCK MURDER	3		8.0	8.0	1245	1545			
05	TELEPHONE BOOTH NYC PL.	3		8.0	8.0	1248	1548	180	1440	
06	FB	1								
07	FB	1								

COMMENTS:

SAMPLE BY: R. FRAVANDI	DATE: 6/24/01
SIGNATURE: <i>[Signature]</i>	DATE:
RELEASED BY: <i>[Signature]</i>	DATE:
SIGNATURE: <i>[Signature]</i>	DATE: 7/1/02
RECEIVED BY: <i>[Signature]</i>	DATE: 8/1/02
SIGNATURE: <i>[Signature]</i>	DATE:

SAMPLE TYPE CODES

1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

Fax #: (212) 922-0630

Date: Monday, July 01, 2002

Time: 1:12:33 PM

Comments:

From: ROMAN PEYSAKHOV

ATC Group #: 8361

Client Project: NYC-DEP W & P File #: 1079.01.02
110 Chamber Street

Number of Pages:

3

(including cover page)

4