

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02
 96-98 Chamber Street

Received: 6/15/02 10:00:00 PM

ATC Group #: 8130

Analysis Date: 6/16/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
01 8130 -1	1440.00	0.0562	0	None Detected	0	0.0048	<17.79 <0.0048	
02 8130 -2	1440.00	0.0562	0	None Detected	0	0.0048	<17.79 <0.0048	
03 8130 -3	1440.00	0.0562	0	None Detected	0	0.0048	<17.79 <0.0048	
04 8130 -4	1260.00	0.0674	0	None Detected	0	0.0045	<14.83 <0.0045	
05 8130 -5	1260.00	0.0674	0	None Detected	0	0.0045	<14.83 <0.0045	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

228 East 46th Street
New York, NY 10017
(212) 922-0977
Fax (212) 922-0630

8130

P.O.

WARREN & PANZER ENGINEERS, P.C. AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

CLIENT: DEP NYC

PROJECT: 96 - 98 CHAMBER ST

LOCATION: FACADE

W&P FILE #: 1019-01-02

TURN AROUND: 24 HRS


TECHNICIAN: R. FORD

Analysis Method: PCM - 7400

(circle one) TEM - AHERA

TEM - EPA LEVEL #

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOW RATE		TIME		TOTAL TIME (HRS)	VOLUME (GAL)	CONCENTRATION (lb./cc)
				START	STOP	ON	OFF			
01	ROOF @ SIDE	3		6.0	6.0	0605	1003	0358	1440	
02	ENTRANCE 96	3		6.0	6.0	0609	1009	0400	1440	
03	9th STEP SIDEWALK	3		6.0	6.0	0612	1012	0400	1440	
04	ENTRANCE 98	3		6.0	6.0	1010	1330	0320	1260	
05	@ SIDE OF 98	3		6.0	6.0	1015	1335	0320	1260	
06	FB	1					NA			
07	FB	1					NA			

SAMPLED BY: R. FORD	DATE: 6-15-01
SIGNATURE: 	
RELEASED BY:	DATE:
SIGNATURE:	
RECEIVED BY: M. Green	DATE: 06.15.01
SIGNATURE:	DATE: 6.15.01

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION