

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC DEP

265-267 Broadway. Roof

Received: 6/8/02

10:00:00 PM

ATC Group #: 8016

Analysis Date: 6/9/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
01 8016 -1	1440.00	0.0562	0	None Detected	0	0	0.0048 <17.79 <0.0048	
02 8016 -2	1440.00	0.0562	0	None Detected	0	0	0.0048 <17.79 <0.0048	
03 8016 -3	1440.00	0.0562	0	None Detected	0	0	0.0048 <17.79 <0.0048	
04 8016 -4	1440.00	0.0562	0	None Detected	0	0	0.0048 <17.79 <0.0048	
05 8016 -5	1440.00	0.0562	0	None Detected	0	0	0.0048 <17.79 <0.0048	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

100 West 60th Street
New York, NY 10017
(212) 922-0877
Fax (212) 922-0830

WARREN & PANZER ENGINEERS, P. C. **AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM**

PAGE 01 OF 02

CLIENT: DEP.

PROJECT: ROOF

LOCATION: 265-267 Broadway

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

W&P FILE #: 1015 01-02

LABORATORY: ATC

ANALYSIS METHOD: PCM
circle one
TEM
HERA
EPA LEVEL II

TECHNICIAN: J. Breyer

CONTACT:

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	ON	OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
060802-01	ROOF NORTH SIDE - E - POOL	3	1	40	6	9:17	13:17	240	1440	
060802-02	ROOF NORTH SIDE - W - POOL	3	1	6	6	9:12	13:19			
060802-03	ROOF NORTH SIDE - W - POOL	3	1	6	6	9:11	13:21			
060802-04	ROOF SOUTH SIDE - W - POOL	3	1	6	6	9:23	13:23			
060802-05	ROOF SOUTH SIDE - W - POOL	3	1	6	6	9:25	13:25	240	1440	
060802-06	ROOF SOUTH SIDE - W - POOL	3	1	6	6	9:25	13:25	240	1440	

COMMENTS:

SAMPLE BY: J. Breyer DATE: 06-08
 SIGNATURE: [Signature]
 RELEASED BY: J. Breyer DATE: 06-08
 SIGNATURE: [Signature]
 RECEIVED BY: H. Gray DATE: 06-08
 SIGNATURE: [Signature]

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 3016

Date: Sunday, June 09, 2002

Client Project: NYC DEP
265-267 Broadway, Roof

Time: 12:49:29 AM

Comments:

Number of Pages: 3
(including cover page)