

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02
173 Broadway

Received: 6/21/02 8:00:00 AM
ATC Group #: 8203
Analysis Date: 6/21/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8203 -1	1330.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
02 8203 -2	1330.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
03 8203 -3	1330.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
04 8203 -4	1330.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
05 8203 -5	1330.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10679

Page 1 of 1

203

Fax (212) 522-0630

WARREN & PANZER ENGINEERS, P.C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

CLIENT: NYC DEP

PROJECT: 173 BOLDVY

LOCATION: ROOF

W&P FILE # 1079-01-022

TURN AROUND: 24 HRS

TECHNICIAN: R. FERNAJDEZ

Analysis Method: ~~PCM-7400~~

(circle one)

LEVEL - 11

[illegible]

SAMPLED BY:	R. FORD	DATE:	6-21-62
SIGNATURE:	[Signature]		
RELEASED BY:	[Signature]	DATE:	
SIGNATURE:			
RECEIVED BY:		DATE:	
SIGNATURE:			

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 6/21/02

8:00:00 AM

ATC Group #: 8203

Analysis Date: 6/21/02

Project: NYC-DEP W & P File #: 1079.01.02

173 Broadway

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µm	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8203 -1	1330.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
02 8203 -2	1330.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
03 8203 -3	1330.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
04 8203 -4	1330.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
05 8203 -5	1330.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10379

Page 1 of 1

TOTAL P.05

28 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

8203

WARREN & PANZER ENGINEERS, P.C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

P.O.

CLIENT: NYC DEP
PROJECT: 113 BROW
LOCATION: ROOF

517

95798
95604

WAP FILE #: 1079-01-02
TURN AROUND: 24 HRS
TECHNICIAN: R. FERLAND

Analysis Method: PCM-7400
(circle one)
TEM - AHERA
TEM - EPA LEVEL II

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	ON	TIME OFF	TOTAL VOLUME (CONCENTRATION)
01	IWA FRONT SIDE BROW (2)	3		7.0	7.0	1140	0250	190 1330
02	IWA FRONT SIDE (1)	3		7.0	7.0	1145	0255	
03	IWA MIDDLE OF ROOF	3		7.0	7.0	1147	0257	
04	IWA ENTRANCE (DOWN)	3		7.0	7.0	1150	0300	
05	REAR SIDE OF ROOF	3		7.0	7.0	1152	0302	190 1330
06	FB	1				NA		
07	FD	1				NA		

BRNM LABORATORY UNIT

JUN-24-2002 16:11

AMPLED BY: R. FERLAND DATE: 6-21-02
 INATURE: 
 LEASED BY: _____ DATE: _____
 INATURE: _____
 CEIVED BY: _____ DATE: _____
 INATURE: _____

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

JUN-24-2002 15:26

P. 02



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

Fax #: (212) 922-0630

Date: Friday, June 21, 2002

Time: 10:25:19 AM

Comments:

From: ROMAN PEYSAKHOV

ATC Group #: 8203

Client Project: NYC-DEP W & P File #: 1079.01.02
173 Broadway

Number of Pages: 3
(including cover page)