

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Fax: (212) 922-0630 **Phone:** (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02
 176 Broadway, Roof

Received: 7/11/02 8:00:00 AM
ATC Group #: 8444
Analysis Date: 7/11/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5 µm	5µ		(S/mm ²)	(S/cc)	
01 8444 -1	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042	
02 8444 -2	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042	
03 8444 -3	1620.00	0.0562	0	CHRYSTOTILE	0	1	0.0042	17.79	0.0042	
04 8444 -4	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042	
05 8444 -5	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10079

P.O.

WARREN & PANZER ENGINEERS, P.C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

CLIENT: NYCD
PROJECT: ROOF
LOCATION: 176 BROOKLYN

W&P FILE #: 1079.01.02
TURN AROUND: 24 HRS
TECHNICIAN: GUY'S SOTO

Analysis Method: PGM - 7400
(circle one) TEM - AHERA
TEM - EPA LEVEL II

[illegible]

SAMPLED BY:	<u>Louis Soto</u>	DATE: <u>7-10-02</u>
SIGNATURE:	<u>[Signature]</u>	
RELEASED BY:	<u>Louis Soto</u>	DATE: <u>7-10-02</u>
SIGNATURE:	<u>[Signature]</u>	
RECEIVED BY:	<u>ATC</u>	DATE <u>7/11/02</u>
SIGNATURE:	<u>[Signature]</u>	<u>800</u>

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8444

Date: Thursday, July 11, 2002

Client Project: NYC DEP. W&P# 1079.01.02
176 Broadway, Roof

Time: 2:22:28 PM

Comments:

Number of Pages: 3
(including cover page)