

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

179 Broadway

Received: 6/21/02

8:00:00 AM

ATC Group #: 8202

Analysis Date: 6/21/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
01 8202 -1	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
02 8202 -2	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
03 8202 -3	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
04 8202 -4	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
05 8202 -5	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101137-0, NY State ELAP #10875

228 East 46th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0830

P.O.

WARREN & PANZER ENGINEERS, P.C. AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

8202


CLIENT: NYC DEP
PROJECT: 179 BRDWAY
LOCATION: FACADE

W&P FILE #: 1079-01-02
TURN AROUND: 24 HRS
TECHNICIAN: R. FERNANDEZ

Analysis Method: PCM-7400
(circle one)
TEM - AHERA
TEM - EPA LEVEL II

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOW RATE		TIME		TOTAL TIME	VOLUME / CONCENTR.	
				START	STOP	ON	OFF		(MG/60)	(MG/60)
01	ROOF (MIDDLE)	3		8.0	8.0	0600	0600	180	1140	
02	RIGHT SIDE FRONT FACADE	3		8.0	8.0	0607	0607			
03	BARREL (SIDE WALK) R 3	3		8.0	8.0	0609	0609			
04	LEFT SIDE (FACADE) FRONT	3		8.0	8.0	0621	0621			
05	BASE OF LEFT (CHERRY BEACH)	3		8.0	8.0	0625	0625	180	1140	
06	FL	1								
07	FL	1								

SAMPLED BY: R. FERNANDEZ DATE: 6-21-02

SIGNATURE: 

RELEASED BY: DATE:

SIGNATURE: DATE:

RECEIVED BY: DATE:

SIGNATURE: DATE:

SAMPLE TYPE CODES			
1 - Blank	5 - Final Clearance (inside)		
2 - Pre-Abatement	6 - Final Clearance (outside)		
3 - During Abatement	7 - Personal		
4 - During Glove Bag Removal	8 - Background		

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warron & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8202

Date: Friday, June 21, 2002

Client Project: NYC-DEP W & P File #: 1079.01.02
179 Broadway

Time: 10:25:29 AM

Comments:

Number of Pages: 3
(including cover page)