

Asbestos Inspection Report

Premise No. 180 BROADWAY					Inspection Date: AS NOTED	
Floor ROOF & FACADE	Zip 10038	Borough 1	Block 65	Lot 18	Squad # N/A	Badge # A020
Inspector Dennis Antzoulatos		Building Type MIXED USE		Basis of Inspection WTC Survey		Photos Taken ☒ Yes / No
Contractor's Name Benjamin Kurzban & Son Control				Sample Number N/A		
Address City 1248 Ralph Avenue, Brooklyn				Sample Number N/A		
State Zip Phone NY 11236 (718)531-2900				Sample Number N/A		
Laboratory Name Warren & Panzer Engineers Inc.				Owner's Name		
Address City 228 East 45 Street New York				Address City		
State Zip Phone NY 10017 (212) 922-0077				State Zip Phone		
Contact Person				Time of Inspection from: AS NOTED		

SUNDAY JULY 14 2002

8:00AM TO 4:00PM THE CLEAN UP OF THE ROOF SURFACE OF THE PREMISE IS CONDUCTED. AIR SAMPLING FOR THIS PORTION OF THE WORK WAS PERFORMED BY CHETRAM RAMRAJ (CERTIFICATE # AH 98-19842 EXP 07/09) FIVE AIR SAMPLES WERE TAKEN. DUE TO SPACE LIMITATIONS STEP-OFF PADS WITH DOUBLE TYVEK SUITS WERE USED IN LIEU OF A REMOTE DECONTAMINATION UNIT.

SUNDAY JULY 21 2002

8:00AM TO 1:00PM CLEAN UP ACTIVITIES ON THE WEST FACADE (BROADWAY FACADE) WERE CONDUCTED. FACADE CLEANING WAS LIMITED TO THE SECOND FLOOR, FIRST FLOOR AND GROUND FLOOR ONLY. THE FACADE CLEANING OF 182 BROADWAY AND 176 BROADWAY WERE PERFORMED SIMULTANEOUSLY FOR THE PURPOSES OF AIR MONITORING THE FACADES OF THESE THREE BUILDINGS WERE CONSIDERED ONE WORK AREA. AIR SAMPLING WAS CONDUCTED BY LUIS SOTO OF WARREN & PANZER. A DYKE WAS CONSTRUCTED TO COLLECT RUN OFF WATER. A DECONTAMINATION UNIT TRUCK WAS UTILIZED.

MONDAY JULY 22 2002 TO THURSDAY JULY 25 2002

CLEAN UP ACTIVITIES WERE CONDUCTED ON THE EAST AND NORTH FACADES OF THE PREMISE. AIR SAMPLING FOR THIS PORTION OF THE WORK WAS CONDUCTED BY EDWIN ELLIS III OF WARREN & PANZER. I CONDUCTED A VISUAL INSPECTION OF THESE AREAS, AFTER CLEAN UP ACTIVITIES WERE COMPLETED, AND I OBSERVED NO VISIBLE WTC DEBRIS. CLEAN UP ACTIVITIES FOR THE SECOND FLOOR SET BACK HAVE NOT YET BEEN SCHEDULED.

Asbestos Inspection Report

Premise No. 180 BROADWAY	Inspection Date: AS NOTED
Inspector Dennis Antzoulatos	Page <u>2</u> of <u>2</u>

FRIDAY AUGUST 2 2002 - SUNDAY AUGUST 4 2002

CLEAN UP ACTIVITIES ON THE SECOND FLOOR SET BACK ROOF AREA ARE CONDUCTED. DUE TO SPACE LIMITATIONS STEP OFF PADS AND DOUBLE-TYVEK SUITS ARE USED IN LIEU OF A REMOTE DECON UNIT. AIR SAMPLING IS PERFORMED BY FESLY OSEMWEGIE (AH 01-01030 EXP 01/03) OF WARDEN & PANZER ENGINEERS. I CONDUCTED A VISUAL INSPECTION OF THE CLEANED SURFACES AND OBSERVED NO VISIBLE WTC DEBRIS. THE CLEAN UP PROJECT AT THIS PREMISE IS NOW COMPLETE.

PL