

TEL :

Sep 15.00

21:37 No.001 P.02

**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel. (718) 794-7988

Fax. (718) 794-0085

CLIENT: Warren &amp; Panzer Engineers, P. C.

LABORATORY ID #: T02-07-076

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

AVERAGE G.O. AREA (mm<sup>2</sup>): 0.008643**AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY**

PROJECT: 2 John Street/180 Broadway

DATE OF REPORT: 07/27/02

DATE OF ANALYSIS: 07/27/02

EFFECTIVE FILTER AREA (mm<sup>2</sup>): 385**LABORATORY RESULTS**

| CLIENT # | LAB. ID #       | LOCATION                   | VOLUME (ft <sup>3</sup> ) | G.O.'s ANALYZED | AREA ANALYZED (mm <sup>2</sup> ) | ANALYT. SENSITIVITY (micrograms/ft <sup>3</sup> ) | TOTAL ASBESTOS AIR CONC. (micrograms/ft <sup>3</sup> ) | TOTAL ASBESTOS FILTER CONC. (micrograms/ft <sup>3</sup> ) | AIR CONC. FOR STRUCT. 0.55-0.9mm | AIR CONC. FOR STRUCT. 0.25-0.9mm | ASBEST. TYPE CHRYE. | ASBEST. TYPE SPECIFY |
|----------|-----------------|----------------------------|---------------------------|-----------------|----------------------------------|---------------------------------------------------|--------------------------------------------------------|-----------------------------------------------------------|----------------------------------|----------------------------------|---------------------|----------------------|
| 1        | T02-07-026-1074 | In remote decon clean room | 1680                      | 6               | 0.0519                           | 0.0044                                            | <0.0044                                                | <19.28                                                    | NA                               | NA                               | NA                  | NA                   |
| 2        | T02-07-026-1075 | Staircase to roof          | 1680                      | 6               | 0.0519                           | 0.0044                                            | <0.0044                                                | <19.28                                                    | NA                               | NA                               | NA                  | NA                   |
| 3        | T02-07-026-1076 | North side of roof         | 1680                      | 6               | 0.0519                           | 0.0044                                            | <0.0044                                                | <19.28                                                    | NA                               | NA                               | NA                  | NA                   |
| 4        | T02-07-026-1077 | East side of roof          | 1680                      | 6               | 0.0519                           | 0.0044                                            | <0.0044                                                | <19.28                                                    | NA                               | NA                               | NA                  | NA                   |
| 5        | T02-07-026-1078 | West side of roof          | 1680                      | 6               | 0.0519                           | 0.0044                                            | <0.0044                                                | <19.28                                                    | NA                               | NA                               | NA                  | NA                   |

ANALYST  
E. SionkinLABORATORY DIRECTOR  
Spiro Deuganis**LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, RELAP 10955**

- Athenica Environmental Services Inc. (AES) is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassette will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test results may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

702-07-026

**COMMENTS:**

| SAMPLE TYPE CODES               |                               |
|---------------------------------|-------------------------------|
| 1 - Blank                       | 5 - Final Clearance (inside)  |
| 2 - Pre-Abatement               | 6 - Final Clearance (outside) |
| <del>3 - During Abatement</del> | 7 - Personal                  |
| 4 - During Glove Bag Removal    | 8 - Background                |

NYC-WTC 000122848