

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02

180 Broadway, Façade

Received: 7/22/02

2:00:00 PM

ATC Group #: 8575

Analysis Date: 7/22/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
01 8575 -1	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
02 8575 -2	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
03 8575 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
04 8575 -4	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
05 8575 -5	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101167-0, NY State ELAP #10879



228 East 45th Street
New York, NY 10017
Tel: (212) 922-0077

FACSIMILE COVER SHEET

DATE: 7/23

FILE #: 600 # 8575

SENDER: _____

FACSIMILE PHONE NUMBER: (212) 922-0630

RECEIVER: Mr. Leonard Atteloney *Kris H*

COMPANY NAME: NYC DEP

FACSIMILE NUMBER: (718) 595-6307 *718-595-3744*

NUMBER OF PAGES (INCLUDING COVER SHEET): 5 *3*

NOTES: *TEM* Please see the attached PCM results sampled on 7/21/02. If you
have any questions, please call me at (212) 922-0077. Thank you.

IF THERE ARE ANY PROBLEMS WITH THIS TRANSMISSION, PLEASE NOTIFY
THE SENDER IMMEDIATELY AT (212) 922-0077.

ORIGINAL SENT VIA:

☒ U.S. MAIL ☐ MESSENGER

☐ OVERNIGHT MAIL ☒ NOT SENT