



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers . P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8015

Date: Sunday, June 09, 2002

Client Project: NYC DEP

Time: 12:16:09 AM

181 Broadway, Roof Clean-Up

Comments:

Number of Pages: 3

(including cover page)

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Pauzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 6/8/02

10:00:00 PM

ATC Group #: 8015

Analysis Date: 6/9/02

Project: NYC DEP

181 Broadway, Roof Clean-Up

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8015 -1	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
02 8015 -2	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
03 8015 -3	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
04 8015 -4	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #10:187-0, NY State ELAP #10879

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P.C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

CLIENT: NYC DEP

PROJECT: 181 BREWERY

LOCATION: ROOF CLEAN-UP

W&P FILE #: 1079-01-012

TURN AROUND: 24 HRS

TECHNICIAN: R. FRYLANDER

P.O. _____

Analysis Method: PCM-7400

(circle one) TEM - AHERA

TEM - EPA LEVEL II

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE		TIME		TOTAL TIME	VOLUME (liters)	CONCENTRATION (ppm)
				START	STOP	ON	OFF			
01	2nd FLOOR WALL R SIDE	3		8.0	8.0	1505	1805	150	1440	
02	2nd FLOOR WALL (L) SIDE	3		8.0	8.0	1507	1807			
03	UPPER ROOF MECH RM (NORTH)	3		8.0	8.0	1509	1809			
04	6th FLOOR STAIRWELL ENTRANCE	3		8.0	8.0	1516	1816	150	1440	
05	FIB	1					NA			
06	FIB	1					NA			

IMPLED BY: R. FRYLANDER
 SIGNATURE:  DATE: 06-08-02
 LEASED BY: _____ DATE: _____
 NATURE: _____ DATE: _____
 RECEIVED BY: H. Garofalo DATE: 06-08-02
 NATURE: _____

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR CONTINUATION