NYC 9/11 Public Portal Document

ATC Associates
104 East 25 Street, New York, NY 10010
Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017
Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02
10-12 Comthand Street

Received: 7/10/02 3:00:00 PM
ATC Group #: 8436
Analysis Date: 7/10/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ<5	# Structures 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
01 8436 -1	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
02 8436 -2	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
03 8436 -3	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
04 8436 -4	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
05 8436 -5	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	

ROMAN PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10579

NYC-WTC_000126306

NYC-WTC_000126307

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr+/a 12 hr+/a 6 hr+/a 3 hr+/a Immediate +/a

P.O. ____

CLIENT: NYC DEP
PROJECT: ROOF OO FACADE
LOCATION: 10-12 Courtland Street

W&P FILE #: 10701:02
LABORATORY: ATC
ANALYSIS METHOD: PCM (circle one) 7400 | TEM AHERA | TEM EPA LEVEL II
TECHNICIAN: Celestine Nnonce

CONTACT: Mike Millar.

8436

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (fib./cc.)
01	By Exit Door (Entrance	3		4	4	0800	1400	360	1440	
02	EAST Center Leg	3		4	4	0802	1402	360	1440	
03	North Lower Leg	3		4	4	0804	1404	360	1440	
04	WEST Center Leg	3		4	4	0806	1406	360	1440	
05	SOUTH Lower Leg	3		4	4	0808	1408	360	1440	
06	BF	1								
07	BF	1								
08	Capped Blank.	1								

COMMENTS:

SAMPLE BY: Celestine Nnonce DATE: 8/10/02
SIGNATURE: C Nnonce
RELEASED BY: Celestine Nnonce DATE: 8/10/02
SIGNATURE: C Nnonce
RECEIVED BY: ____ DATE: 8/10/2
SIGNATURE: ____ 1500

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

NYC 9/11 Public Portal Document

NYC 9/11 Public Portal Document

ATC Associates Inc.
104 East 25 Street
New York, NY 10010
TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

Fax #: (212) 922-0630

Date: Wednesday, July 10, 2002

Time: 10:39:35 PM

Comments:

From: ROMAN PEYSAKHOV

ATC Group #: 8436

Client Project: NYC DEP, W&P# 1079.01.02
10-12 Cornband Street

Number of Pages: 3
(including cover page)

4