

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 7/9/02

4:20:00 PM

ATC Group #: 8423

Analysis Date: 7/9/02

Project: NYC DEP, W&P# 1079.01.02

10-12 Courtlands Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Analytical		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					# Structures 0.5µ-5 µ	5µ		(S/mm ²)	(S/cc)	
09 8423 -1	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
10 8423 -2	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
11 8423 -3	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
12 8423 -4	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
13 8423 -5	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

8

**228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630**

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE _____ OF _____

923

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

P.O.

W&P FILE #: 1079:01:02

CONTACT: Mike Nelson

CLIENT: WMC DEP

LABORATORY: A-7C

PROJECT: ROOF CLEANING

ANALYSIS METHOD:	PCM	TEM	TEM

TEM
HERA EPA LEVEL II

LOCATION: 10-12 Courtland St.

TECHNICIAN: Celestine Hines

[illegible]

COMMENTS:

SAMPLE BY: CRISTIANE MINVILLO DATE: 7/9/02

SIGNATURE: CD

RELEASED BY: Collegiate Nursing DATE: 07/07/07

SIGNATURE: Chen H. H. DATE: 3/8

RECEIVED BY: _____
SIGNATURE: _____
DATE: 11/1/88

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

ATC Group #: 8423

Fax #: (212) 922-0630

Client Project: NYC DEP. W&P# 1079 01.02
10-12 Courtlands Street

Date: Tuesday, July 09, 2002

Time: 10:13:21 PM

Comments:

Number of Pages: 3
(including cover page)

7