


ATHENICA

 ENVIRONMENTAL SERVICES INC.
 Tel. (718) 704-7400
 Fax. (718) 704-4065

CLIENT: Warren & Panzer Engineers, P.C.

LABORATORY ID #: T02-08-112

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

 AVERAGE G.O. AREA (mm²): 0.012412

PROJECT: NYC DEP, 200 Church St.

DATE OF REPORT: 08/23/02

DATE OF ANALYSIS: 08/22/02

 EFFECTIVE FILTER AREA (mm²): 385

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (ft ³)	G.O. ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIVITY (micrograms/cm ²)	TOTAL ASBESTOS AIR CONC. (micrograms/cm ³)	TOTAL ASBESTOS FILTER CONC. (micrograms/cm ²)	AIR CONC. FOR STRUCT. 0.55-5.0um	AIR CONC. FOR STRUCT. >5.0um	ASBEST. TYPE CHYS.	AMPHIB. ASBEST. TYPE SPECIFY
01	T02-08-112-1782	By Entrance	1320	5	0.0621	0.0047	<0.0047	<16.10	NA	NA	NA	NA
02	T02-08-112-1783	Inside work area South	1320	5	0.0621	0.0047	0.0047	16.10	<0.0047	0.0047	Chrys.	NA
03	T02-08-112-1784	Inside work area West	1320	5	0.0621	0.0047	<0.0047	<16.10	NA	NA	NA	NA
04	T02-08-112-1785	Inside work area East	1320	5	0.0621	0.0047	<0.0047	<16.10	NA	NA	NA	NA
05	T02-08-112-1786	Inside work area North	1320	5	0.0621	0.0047	<0.0047	<16.10	NA	NA	NA	NA

 ANALYST
 F. Sionettri

 LABORATORY DIRECTOR
 Spiro Doaganis

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Air sampling cassette will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc., with respect to the services charged, shall in no event exceed the amount of the invoice.

**2225 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0030**

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

Fax (212) 922-0830

CLIENT: NYC DEP

PROJECT: ROOF CLEANING

LOCATION: 200 Church ~~Street~~

$24 \text{ hr} + 12$

W&P FILE #: 1079:05:02

LABORATORY: JTC

ANALYSIS METHOD: PCM
cycle one 7400

TECHNICIAN: Collette Hynock

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate⁺/a

A

TEM
AHEBA
EPA LEVI

4/10/2019

CONTACT: Mr Mike Abdon

洋人門

SCA JOB#:

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
01	By Entrance	3		04 04	0730 1300	330	1320	
02	Inside work area South	3		04 04	0732 1302	1330	1320	
03	Inside work area West	3		04 04	0734 1304	330	1320	
04	Inside work area East	3		04 04	0736 1306	330	1320	
05	Inside work area North	3		04 04	0738 1308	330	1320	
06	BF	1						
07	BF	1						
08	Capped Blank	1						

COMMENTS:

SAMPLE BY: Colestina Nimmag DATE: 08/22/12

SIGNATURE: *[Signature]*

RELEASED BY: Celestine Norvige DATE: 08/22/02

SIGNATURE: *[Signature]*

RECEIVED BY: A-CAT 11-2-81 DATE: 11-2-81

SIGNATURE: _____

T02-08-112

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION