

8:21 NO.002 P.06

DEC 25,00

TEL:

**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel. (718) 784-3498

Fax. (718) 784-4085

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY**CLIENT:** Warren & Panzer Engineers, P.C.**LABORATORY ID #:** T02-11-006**ANALYT. METHODOLOGY:** AHERA**FILTER TYPE:** M.C.E.**AVERAGE G.O. AREA (mm²):** 0.013433**PROJECT:** NYC DEP, 100 Church Street**DATE OF REPORT:** 11/02/02**DATE OF ANALYSIS:** 11/02/02**EFFECTIVE FILTER AREA (mm²):** 385**LABORATORY RESULTS**

CLIENT #	LAB ID #	LOCATION	VOLUME (ft)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIV. (struct./cm ²)	TOTAL ASBESTOS AIR CONC. (struct./cm ²)	TOTAL ASBESTOS FILTER CONC. (ppm/mm ²)	AIR CONC. FOR STRUCT. 0.555-5.555 ppm	AIR CONC. FOR STRUCT. 5.555-55.555 ppm	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
01	T02-11-006-3705	Decon clean room	1395	5	0.0672	0.0041	<0.0041	<14.89	NA	NA	NA	NA
02	T02-11-006-3706	South west	1395	5	0.0672	0.0041	<0.0041	<14.89	NA	NA	NA	NA
03	T02-11-006-3707	Center roof area south side	1395	5	0.0672	0.0041	0.0082	29.78	0.0082	<0.0041	Chrys.	NA
04	T02-11-006-3708	Center roof area south side	1395	5	0.0672	0.0041	0.0082	29.78	0.0041	0.0041	Chrys.	NA
05	T02-11-006-3709	South east	1440	4	0.0537	0.0050	<0.0050	<18.61	NA	NA	NA	NA

ANALYST
E. Dimitrakas

LABORATORY DIRECTOR
Spiro Danganis**LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10055**

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling canisters will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

NYC-WTC_000126827