

TEL :

Dec 25, 00

7:17 No.001 P.04

**ATHENICA**

ENVIRONMENTAL SERVICES INC.

TEL (718) 794-7900
FAX (718) 794-4005**AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY**

CLIENT: Warren & Panzer Engineers, P.C.

LABORATORY ID #: T02-11-015

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

AVERAGE G.O. AREA (mm²): 0.013433

PROJECT: NYC DEP, 109 Church Street

DATE OF REPORT: 11/03/02

DATE OF ANALYSIS: 11/03/02

EFFECTIVE FILTER AREA (mm²): 385**LABORATORY RESULTS**

CLIENT #	LAB ID #	LOCATION	VOLUME (B)	G.O.'s ANAL. V280	AREA ANAL. ZAD (mm ²)	ANALYT. SENSITIV. (picogram)	TOTAL ASBESTOS AIR CONC. (picogram)	TOTAL ASBESTOS FILTER CONC. (picogram)	AIR CONC. FOR STRUCT. 0.45-0.6um	AIR CONC. FOR STR. CT. 0.75-0.9um	ASBEST. TYPE CHYS	AIRBOR. ASBEST. TYPE SPECIFY
01	T02-11-015-3750	Docum	1416	5	0.0672	0.0040	<0.0040	<14.89	NA	NA	NA	NA
02	T02-11-015-3751	Southeast by stairway/utility room	1401	5	0.0672	0.0041	0.0041	14.89	<0.0041	0.0041	CHYS	NA
03	T02-11-015-3752	South east by west corner	1377.6	5	0.0672	0.0042	0.0083	28.78	0.0041	0.0041	CHYS	NA
04	T02-11-015-3753	South east - east side	1377.6	5	0.0672	0.0042	<0.0042	<14.89	NA	NA	NA	NA
05	T02-11-015-3754	South east - east side	1530	4	0.0337	0.0047	<0.0047	<18.61	NA	NA	NA	NA

ANALYST
E. Dimitrakas

LABORATORY DIRECTOR
Spyro Donaganis**LABORATORY CERTIFICATION NUMBERS: NVLAP 101959, ELAP 10955**

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling equipment will be stored for sixty (60) days. AES Inc. should be notified within this time frame for a time extension, analysis.
- If AES Inc. did not conduct the sampling, the reported asbestos concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

440 EAST 42ND STREET
NEW YORK, NY 10017
(212) 922-0077
FAX (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate⁺/a

PAGE ____ OF ____
P.O. _____

CLIENT: Wye-Dee-

PROJECT: Paris & Friends

LOCATION: 600 CHERRY ST -

W&P FILE # 1037 01 07

LABORATORY: ~~NYC-22~~

ANALYSIS METHOD: PCM TEM TEM

circle one

7400

~~AMERICA~~ EPA LEVEL N

CONTACT: PA Helms -

TECHNICIAN: J. B. [unclear]

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (bars)	CONCENTRATION (bars)
01	Dev	3	1	4	4	10:00	10:15	35.4	1414	
02	Seawater by straining facility Am.	3	1	4	4	10:33	10:17	35.4	1401	
03	Seawater by straining facility Am.	3	1	4	4	10:37	10:18	34.4	1372.6	
04	Seawater by straining facility Am.	3	1	4	4	10:45	10:11	34.4	1372.6	
05	Seawater by straining facility Am.	3	1	5	5	11:10	11:20	30.6	1530	
06	Field data	1	1							
07	Field data	1	1							

COMMENTS:

702-11-015

SAMPLE BY: J. B. [unclear] DATE: 01-03-07

SIGNATURE: Q. Rogers

RELEASED BY: QJH DATE: 11-22-92

SIGNATURE: Chapman

RECEIVED BY: A. CAILLIAU DATE: 11/3/07

SIGNATURE: [Signature]

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION