

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017
 Fax: (212) 922-0630 Phone: (212) 922-0077
 Project: NYC DEP, W&P# 1079.01.02
 148 Chambers Street, Façade

Received: 7/15/02 7:00:00 AM
 ATC Group #: 8497
 Analysis Date: 7/15/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Analytical Sensitivity		Asbestos Concentration		Notes
					0.5µ-5 µm	5µ	(S/cc)	(S/mm ²)	
001A 8497 -1	1450.00	0.0562	0	None Detected	0	0	0.0047	<17.79	<0.0047
002A 8497 -2	1450.00	0.0562	0	None Detected	0	0	0.0047	<17.79	<0.0047
003A 8497 -3	1450.00	0.0562	0	CHRYSTILE	0	1	0.0047	17.79	0.0047
004A 8497 -4	1450.00	0.0562	0	None Detected	0	0	0.0047	<17.79	<0.0047
005A 8497 -5	1450.00	0.0562	0	None Detected	0	0	0.0047	<17.79	<0.0047

5

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers . P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8497

Date: Monday, July 15, 2002

Client Project: NYC DEP. W&P# 1079.01.02
148 Chambers Street, Facade

Time: 11:21:18 AM

Comments:

Number of Pages: 3
(including cover page)

4