

FIBER CONTROL, INC.

3010 BURNS AVENUE
WANTAGH, NY 11793
(516) 781-3000
FAX (516) 781-3085

INVOICE**REVISED 8-13-02**

Date: **08/08/02**
Due Date:

Inv. No.: **F1088**
Page No.: **1**

**BILL TO: New York City Dept of
Environmental Protection
Asbestos Control Program
59-17 Junction Blvd
Flushing, NY 11373-5108
Att: Alphonso Plumptre
Deputy Lab Director Supervising I.H.**

JOB SITE: job sites listed below

REFERENCE	TERMS	YOUR #	OUR #	SALES REP
TEL: 718-595-3671	Upon Completion	CONTRACT ROF-REM1	F1088	PG

DESCRIPTION REFERENCE	UNIT MEASURE	QUANTITY	UNIT PRICE		EXTENDED PRICE
				ITEM DISCOUNT	
Exterior Cleanup					
<u>Address</u>	<u>Asphalt Roof</u>	<u>Unit Price</u>	<u>facade</u>	<u>Unit Price</u>	<u>Total</u>
92 Reade Street	1500 sq ft @	1.48			\$ 2,220.00 ✓
94 Reade Street	1500 sq ft @	1.48			\$ 2,220.00 ✓
92-94 Warren Street	4900 sq ft @	1.48			\$ 7,252.00 ✓
92-94 Warren Street			3750 sq ft @	2.50	\$ 9,375.00 ✓
150-152 Chambers Street	3400 sq ft @	1.48			\$ 5,032.00 ✓
150-152 Chambers St (ACP-8)	750 sq ft @	1.48			\$ 1,110.00 ✓
75 Murray	1450 sq ft @	1.48			\$ 2,146.00 ✓
75 Murray			1875 sq ft @	2.50	\$ 4,687.50 ✓
121 Chambers Street			1950 sq ft @	2.50	\$ 4,875.00 ✓
121 Chambers St (103 Reade St)			1950 sq ft @	2.50	\$ 4,875.00 ✓
97 Chambers	7052 sq ft @	1.48			<u>\$ 10,436.96</u>
					\$ 54,229.46


WWW.ACTIONHAZMAT.COM

SUB TOTAL	\$ 54,229.46
TAX	0.00
TOTAL	\$ 54,229.46
NET TO PAY	


Krish
E 117 WTC

ONLY
TYPEWRITTEN
FORMS WILL BE
ACCEPTED



NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION
Asbestos Control Program
59-17 Junction Boulevard, 8th Floor, Corona, NY 11368-5107

ASBESTOS PROJECT NOTIFICATION
(ASBESTOS INSPECTION REPORT)



When submitting this form at the NYC Department of Buildings, the original form and three (3) copies with original signatures are required. Submittal at the NYC DEP requires one copy of the form with original signatures. This form must be submitted to the NYC DEP not less than one week in advance of the start of abatement activities.

I. FACILITY

2. Address 150-152 CHAMBERS STREET Borough N.Y. Zip 10007
AKA _____ 3. Block 137 4. Lot 7501
5. Type of Facility _____ 6. Name of Building _____

II. BUILDING OWNER

7. Name 150-152 CHAMBERS ST CONDOMINIUM ASSN 8. Contact Person Daniel Ushander
9. Tel. # _____ Fax # _____
10. Address 122 MONTAGUE ST City BROOKLYN State N.Y. Zip 11201

III. GENERAL CONTRACTOR

11. Name _____ Tel. # _____

IV. ASBESTOS ABATEMENT CONTRACTOR

12. Name FIBER CONTROL 13. Contact Person TONY COSTA
14. Federal Employer ID. # PII 15. Tel. # 516-781-3000 Fax # 516-781-3085
16. Address 3010 BURNS AVE City WANTASH State NY Zip 11793

V. THIRD PARTY AIR MONITOR

17. Name WARREN & PANZER ENGINEERS, PC 18. Contact Person MICHAEL NOLAN
19. Federal Employer ID. # _____ 20. Tel. # 212-922-0077 Fax # 212-922-0630
21. Address 228 EAST 45th STREET City NEW YORK State NY Zip 10017
22. Sample Analysis Laboratory SCIENTIFIC LABORATORIES, Inc 23. NYS DOH ELAP # 11480

VI. PROJECT INFORMATION

24. Starting date for this portion of work 7/31/02 Projected completion date 8/31/02

Asbestos work schedule ☐ Monday ☐ Tuesday ☐ Wednesday ☐ Thursday ☐ Friday ☐ Saturday ☐ Sunday

Shift from: _____ am ☐ pm to _____ am ☐ pm

If other,
specify _____

Access to inspect the premises must be provided during the work schedule indicated in this item.

25. Total amount of asbestos-containing material to be abated during this work

3400 Square Feet, and/or _____ Linear Feet



ACP 7
2/2001

DEP
BUREAU OF ENVIRONMENTAL
REGULATION & ENFORCEMENT
ASBESTOS CONTROL
PROGRAM
10/12

ASBESTOS INSPECTION REPORT (continued)

26. Asbestos Hauler LOGANO NYS DEC Permit # CT-098 Tel. # 800-272-3867

Disposal Site(s) Southern Alleghenies, Valley Landfill

27. This asbestos abatement is part of a (Item a through e requires filing of this form with NYC Department of Buildings)

- a) ☐ Demolition b) ☐ Boiler Replacement c) ☐ Sprinkler Replacement d) ☐ Renovation/Alteration
e) ☐ Fireproofing Replacement f) ☐ Other (Describe) _____

28. TYPE OF ABATEMENT (Check all appropriate boxes)

- ☐ Removal ☐ Enclosure ☐ Encapsulation ☐ Repair ☐ Clean up




29. ABATEMENT PROCEDURE (Check all appropriate boxes)

- ☐ Full Containment ☐ Glovebag ☐ Tent ☐ DEP Variance Application

30. LOCATIONS OF ABATEMENT

Floor(s)	DESCRIBE SECTION OF FLOOR (e.g. entire, east wing, room #, boiler room, lobby, etc.)	AFFECTED SURFACES CONTAINING ACM (e.g. Pipe lagging, ceiling, plenum ducts, storage tanks, decking, etc.)	AMOUNT OF ACM SQUARE FEET LINEAR FEET	DESCRIPTION OF WORK BEING PERFORMED (e.g. running cable, installing fire sprinklers, removing and replacing boilers, etc.)
Roof	(Asphalt)		3400	

31. I hereby declare that the information provided herein is true and complete to the best of my knowledge. I am familiar with Federal, State and NYC laws and regulations applicable to asbestos related work.

<u>BOSUN OGUNWALE</u> Print Name of Air Monitor  Signature <u>06-03-02</u> Date	<u>ANTHONY COSTA</u> Print Name of Asbestos Contractor  Signature <u>6-3-02</u> Date	<u>ANTHONY COSTA</u> Print Name of Applicant (if other than Owner)  Signature <u>6-3-02</u> Date
--	---	---

32. I understand that as the owner of a building where asbestos abatement activity occurs, I am responsible for the performance of the asbestos abatement activities in accordance with the Asbestos Control Program Rules. I have contracted the third party air monitor who is completely independent of all parties involved in the asbestos project. I hereby declare that I have authorized the filing of this notification for the work specified herein.

Alphonso Plungtre  7/31/02
Print Name of Owner Signature Date

A STAMPED COPY OF THIS FORM INCLUDING AMENDMENTS MUST BE AVAILABLE AT THE WORK SITE.

Any modification of information provided on this form must be reported immediately in writing directly to the NYC DEP ACP.

The requirements of the Asbestos Control Program Rules may not be lawfully avoided or lessened through the performance of work in incremental or piecemeal fashion.

08/01/2002 13:03 FAX 718 784 4085

002/003



ATHENICA

ENVIRONMENTAL SERVICES INC.

Tel. (718) 784-7490
Fax. (718) 784-4085

CLIENT: Warren & Panzer Engineers, P. C.
LABORATORY ID #: T02-07-050
ANALYT. METHODOLOGY: AHERA
FILTER TYPE: M.C.E.
AVERAGE G.O. AREA (mm²): 0.012422

PROJECT: NYC DEP, 150/152 Chambers Street
DATE OF REPORT: 08/01/02
DATE OF ANALYSIS: 08/01/02
EFFECTIVE FILTER AREA (mm²): 385

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (l)	G.O. ANAL. VZED	AREA ANALY ZED (mm ²)	ANALYT. SENSITV. (stret./cm ²)	TOTAL ASBESTOS AIR CONC. (stret./cm ²)	TOTAL ASBESTOS FILTER CONC. (stret./mm ²)	AIR CONC. FOR STRUCT. 0.5<S<5µm	AIR CONC. FOR STRUCT. S≥5.0µm	ASBEST. TYPE CRYST.	AMPHIB. ASBEST. TYPE SPECIFY
1A	T02-07-050-1202	Entrance on east side of roof	1560	4	0.0497	0.0050	<0.0050	<20.13	NA	NA	NA	NA
2A	T02-07-050-1203	Entrance on west side of roof	1680	4	0.0497	0.0046	<0.0046	<20.13	NA	NA	NA	NA
3A	T02-07-050-1204	Center area on deck	1680	4	0.0497	0.0046	<0.0046	<20.13	NA	NA	NA	NA
4A	T02-07-050-1205	South on deck	1680	4	0.0497	0.0046	<0.0046	<20.13	NA	NA	NA	NA
5A	T02-07-050-1206	North on deck	1680	4	0.0497	0.0046	<0.0046	<20.13	NA	NA	NA	NA

ANALYST
E. Stoukri

LABORATORY DIRECTOR
Spiko Dengaris

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Athenica Environmental Services Inc. (AES) is a registered, independent laboratory.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc. should be notified within this time frame for a true duplicate analysis.
- If AES Inc. did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- This report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

PAGE 1 OF 1

P.O.

CLIENT: NYP-DEP

W&P FILE #: 1079-01-02

LABORATORY:

CONTACT: Mike Nolan

PROJECT: Rockaway Chambers

LOCATION: 150-15 Chambers

ANALYSIS METHOD: PCM TEM
circle one 7400 (AHERA) EPA LEVEL II

TECHNICIAN: N. Wells

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	ON	OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
001A	Entrance on East side of roof	3		4	4	07:00	03:30	03:30	1560	
002A	Entrance on West side of roof	3		4	4	07:01	13:31	03:30	1560	
003A	Entrance on deck	3		4	4	07:02	13:32	03:30	1560	
004A	South side of deck	3		4	4	07:03	13:33	03:30	1560	
005A	North side of deck	3		4	4	07:04	13:34	03:30	1560	
006	Field	1								
007	Field	1								
008	Field	1								

SAMPLE BY: <u>N. Wells</u>	DATE: <u>7/24</u>
SIGNATURE: <u>N. Wells</u>	DATE: _____
RELEASED BY: _____	DATE: _____
SIGNATURE: _____	DATE: <u>7/24/02</u>
RECEIVED BY: <u>E. Simpson</u>	DATE: <u>7/24/02</u>
SIGNATURE: <u>ES</u>	DATE: _____

702-07-050

SAMPLE TYPE CODES			
1 - Blank	5 - Final Clearance (inside)		
2 - Pre-Abatement	6 - Final Clearance (outside)		
3 - During Abatement	7 - Personal		
4 - During Glove Bag Removal	8 - Background		

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

ASBESTOS INSPECTION REPORT

PAGE 1 OF

REMISE NO.		STREET				INSPECTION DATE	
150-152		CHAMBERS STREET				7-31-02	
LOOR	ZIP	BORO CODE	BLOCK	LOT	SQUAD #	BADGE #	
Roof	10007	1	137	750	1	AD10	
INSPECTOR		BLDG TYPE	BASIS OF INSPECT.			PHOTOS TAKEN YES / NO	
ALPHONSO PLUMPTRE			TRU 1202MNA				
CONTRACTORS NAME				SAMPLE NO.			
FIBER CONTROL							
ADDRESS				CITY			
3010 BURNS AVE				WANTAGH			
STATE		ZIP	PHONE	SAMPLE NO.			
N.Y		11793	(516) 781-3000				
LABORATORY NAME				OWNERS NAME			
WARREN & PANZER ENGINEERS, PC				150-152 Condominium ASSO			
ADDRESS		CITY		ADDRESS		CITY	
228 E. 45TH ST		N.Y		150 Chambers St		N.Y	
STATE		ZIP	PHONE	STATE		ZIP	PHONE
N.Y		10017	(212) 922-0077	N.Y		10007	
CONTACT PERSON:				TIME OF INSPECTION FROM: 1:00 am/pm TO: 1:30 am/pm			
INSPECTION DISCLOSED:							

The roof was cleaned and was later visually inspected. There was no visible debris observed after the cleaning.

On 8/3/02 we gained access to the back setback through the tenants at 80 Warren St. The setback was cleaned but I could not measure it from my previous inspection due to no access. The setback was cleaned and was inspected. No visible debris observed after the cleaning.

NOV #	INFRACTIONS					RESULT CODE
						5
NOV #						SUPERVISORS INITIALS
						W

BORO 1 - MANHATTAN 2 - BRONX 3 - BROOKLYN 4 - QUEENS 5 - RICHMOND

BLDG TYPE A > 6 Stories B < 6 Stories C Single Family
D School E Hospital F Public Owned Property

RESULT CODES 1 - Violation Issued 2 - No Violations Issued 3 - No Access
4 - Project not Started (No NOV) 5 - Project Completed (No NOV)

ACP 309

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

CLIENT: Warren & Panzer Engineers, P. C.

PROJECT: NYC DEP, 150/152 Chamber

LABORATORY ID #: T02-08-014

DATE OF REPORT: 08/05/02

ANALYT. METHODOLOGY: AHERA

DATE OF ANALYSIS: 08/04/02

FILTER TYPE: M.C.E.

EFFECTIVE FILTER AREA (mm²): 385AVERAGE G.O. AREA (mm²): 0.012422**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel: (718) 784-7490

Fax: (718) 784-4085

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (l)	G.O.% ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIVITY (struct./cm ²)	TOTAL ASBESTOS AIR CONC. (struct./cm ²)	TOTAL ASBESTOS FILTER CONC. (air./mm ³)	AIR CONC. FOR STRUCT. 0.55S-5µm	AIR CONC. FOR STRUCT. 8-10µm	ASBEST. TYPE CHYS.	ANALYT. ASBEST. TYPE SPECIFY
01	T02-08-014-1268	Entrance	1350	5	0.0621	0.0046	<0.0046	<16.10	NA	NA	NA	NA
02	T02-08-014-1269	Inside work area south	1350	5	0.0621	0.0046	<0.0046	<16.10	NA	NA	NA	NA
03	T02-08-014-1270	Inside work area west	1350	5	0.0621	0.0046	<0.0046	<16.10	NA	NA	NA	NA
04	T02-08-014-1271	Inside work area center	1350	5	0.0621	0.0046	<0.0046	<16.10	NA	NA	NA	NA
05	T02-08-014-1272	Inside work area east	1350	5	0.0621	0.0046	<0.0046	<16.10	NA	NA	NA	NA

ANALYST
E. SioukriLABORATORY DIRECTOR
Cyrus Dzungaris

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

