

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
226 E. 45th Street
New York NY 10017

Received: 7/15/02 7:00:00 AM
ATC Group #: 8496
Analysis Date: 7/15/02

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02
144 Chambers Street, Façade

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Notes
001A 8496 -1	1350.00	0.0674	0	None Detected	0	0.0042	<14.83	<0.0042
002A 8496 -2	1350.00	0.0674	0	None Detected	0	0.0042	<14.83	<0.0042
003A 8496 -3	1350.00	0.0674	0	None Detected	0	0.0042	<14.83	<0.0042
004A 8496 -4	1350.00			Not Analyzed				No Filter in the Cassett
005A 8496 -5	1350.00	0.0674	0	None Detected	0	0.0042	<14.83	<0.0042

2

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-C, NY State ELAP #10879

WARREN & PANZER ENGINEERS, P.C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0530

P.O.

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

CONTACT: Mike Nolan

W&P FILE #: 1579 d102

CLIENT: NED DEP

LLW#:

LABORATORY: RTC

PROJECT: FACADE CLEANING

SCA JOB#:

ANALYSIS METHOD: PCM TEM
circle one 7400 AHERA EPA LEVEL II

LOCATION: 144 Chambers St

TECHNICIAN: N Wells

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (mg/sec.)
001A	10' adj to entrance 7 bldg	3		10	10	07:30	09:45	135	1350	
002A	Center area another bldg	3		10	10	07:31	09:40	135	1350	
003A	Right side adj to 11 bldg	3		10	10	07:32	09:47	135	1350	
004A	Left side adj to 6 bldg	3		10	10	07:33	09:48	135	1350	10:10
005A	Street air	3		10	10	07:34	09:49	135	1350	
006A	field	1								
007A	field	1								
008A	field	1								

COMMENTS:

SAMPLE BY: [Signature] DATE: 9/11

SIGNATURE: _____ DATE: _____

RELEASED BY: _____ DATE: _____

SIGNATURE: _____ DATE: 7/15/02

RECEIVED BY: RTC

SIGNATURE: [Signature]

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8496

Date: Monday, July 15, 2002

Client Project: NYC DEP. W&P# 1079.01.02
144 Chambers Street, Facade

Time: 10:51:31 AM

Comments:

Number of Pages: 3
(including cover page)

Leonard / Krish

36 Pages