

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Received: 7/12/02 4:15:00 PM

ATC Group #: 8472

Analysis Date: 7/13/88

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02
 145 Chambers Street, Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8472 -1	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
02 8472 -2	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
03 8472 -3	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
04 8472 -4	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
05 8472 -5	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

**228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630**

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

Fax (212) 922-0630

CLIENT #4C DEP

PROJECT: 145 CHAMBER STREET

LOCATION: 106F Clearing

W&P FILE #: 107961: 02

LABORATORY: ATC

ANALYSIS METHOD: PCM
circle one

TECHNICIAN

CONTACT: BYN twice M-L-APL

[illegible]

COMMENTS:

SAMPLE BY: Colastine K. Moore DATE: 07/11/02

SIGNATURE: C. M. J.

RELEASED BY: Debra Ann McGee DATE: 6/12/02

SIGNATURE: C. Smith

RECEIVED BY: ATC DATE: 7/12/02

SIGNATURE: [Signature] 6:15

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 3472

Date: Wednesday, July 13, 1988

Client Project: NYC DEP. W&P# 1079.01.02
145 Chambers Street, Roof

Time: 1:46:39 PM

Comments:

Number of Pages:

3

(including cover page)