

08/12/2002 09:35 FAX 718 784 4085

002

**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel. (718) 784-7680
Fax. (718) 784-4085

CLIENT: Warren & Panzer Engineers, P.C.
LABORATORY ID #: T02-08-048
ANALYT. METHODOLOGY: AHERA
FILTER TYPE: M.C.E.
AVERAGE G.O. AREA (mm²): 0.012422

PROJECT: NYC DEP, 121 Chamber Street
DATE OF REPORT: 08/11/02
DATE OF ANALYSIS: 08/11/02
EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (ft ³)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITV. (microgram/cm ²)	TOTAL ASBESTOS AIR CONC. (microgram/cm ³)	TOTAL ASBESTOS FILTER CONC. (microgram/cm ²)	AIR CONC. FOR STRUCT. 0.55-4um	AIR CONC. FOR STRUCT. >2.50um	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
01	T02-08-048-1446	Inside work area east	1500	5	0.0621	0.0041	<0.0041	<16.10	NA	NA	NA	NA
02	T02-08-048-1447	Inside work area north	1500	5	0.0621	0.0041	<0.0041	<16.10	NA	NA	NA	NA
03	T02-08-048-1448	Inside work area center	1500	5	0.0621	0.0041	<0.0041	<16.10	NA	NA	NA	NA
04	T02-08-048-1449	Inside work area south	1500	5	0.0621	0.0041	<0.0041	<16.10	NA	NA	NA	NA
05	T02-08-048-1450	Inside work area west	1500	5	0.0621	0.0041	<0.0041	<16.10	NA	NA	NA	NA

ANALYST
E. Stokku

LABORATORY DIRECTOR
Spiru Donagis

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Athenica Environmental Services Inc. (AES) is responsible only for information pertaining to samples taken by its employees.
- Air sampling sessions will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a new duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report reflects only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

WARREN & PANZER ENGINEERS, P.C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

08/13/2002 18:55 FAX 718 784 4085

PAGE 1 OF 1

P.O.

24 hr/24

12 hr/24 6 hr/24 3 hr/24 Immediate 2/4

WSP FILE #: 1079101102

CONTACT: Mr Mike Nolan

CLIENT: NYC DEP

LABORATORY: AEC

PROJECT: Side Facades

ANALYSIS METHOD: PCM TEM
circle one 7400 AHERA EPA LEVEL II

LOCATION: 121 Chambers Street

TECHNICIAN: Celestine Alvarez

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP	FLOW RATE	STOP	ON	OFF	TOTAL VOLUME	CONCENTRATION
01	Inside work area East	3		10	10	0600	0830	150	1500
02	Inside work area North	3		10	10	0600	0832	150	1500
03	Inside work area Center	3		10	10	0604	0834	150	1500
04	Inside work area South	3		10	10	0606	0836	150	1500
05	Inside work area West	3		10	10	0608	0838	150	1500
06	Blank	1							
07	Blank	1							
08	Capped Blank	1							

COMMENTS:

T02-02-048

SAMPLE BY: Celestine Alvarez	DATE: 08/13/02
SIGNATURE: [Signature]	
RELEASED BY: Celestine Alvarez	DATE: 08/13/02
SIGNATURE: [Signature]	
RECEIVED BY: A. C. ALVAREZ	DATE: 8/13/02
SIGNATURE: [Signature]	

1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION