


ATHENICA

ENVIRONMENTAL SERVICES INC.

Tel. (718) 704-7490

Fax. (718) 704-4885

CLIENT: Warren & Panzer Engineers, P.C.

LABORATORY ID #: T02-09-118

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

 AVERAGE G.O. AREA (mm²): 0.013838

PROJECT: NYC DEP, 92 Fulton Street

DATE OF REPORT: 09/30/02

DATE OF ANALYSIS: 09/30/02

 EFFECTIVE FILTER AREA (mm²): 385

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (L)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITV. (st/cc/cm ²)	TOTAL ASBESTOS AIR CONC. (st/cc/cm ²)	TOTAL ASBESTOS FILTER CONC. (st/cc/cm ²)	AIR CONC. FOR STRUCT. 0.53-5.0um	AIR CONC. FOR STRUCT. ≥5.0um	ADDITIONAL TYPE CHRG'S.	ASBEST TYPE SPECIFY
01	T02-09-118-2680	East side of facade	1800	4	0.0354	0.0039	<0.0039	<18.07	NA	NA	NA	NA
02	T02-09-118-2681	Center 1	1800	4	0.0354	0.0039	<0.0039	<18.07	NA	NA	NA	NA
03	T02-09-118-2682	Center 2	1800	4	0.0354	0.0039	<0.0039	<18.07	NA	NA	NA	NA
04	T02-09-118-2683	Center 3	1800	4	0.0354	0.0039	<0.0039	<18.07	NA	NA	NA	NA
05	T02-09-118-2684	West side of facade	1800	4	0.0354	0.0039	<0.0039	<18.07	NA	NA	NA	NA

E. Sioukri

ANALYST

E. Sioukri

LABORATORY DIRECTOR

Sprio Domingas

LABORATORY CERTIFICATION NUMBERS: NVLAP 181958, ELAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

