

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Received: 6/24/02 7:00:00 AM
 ATC Group #: 8251
 Analysis Date: 6/24/02

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02
 125 Fulton Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Analytical		Sensitivity (S/cc)	Asbestos		Notes
					# Structures 0.5µ-5 µ	3µ		Concentration (S/mm ²)	(S/cc)	
03 8251 -1	1320.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043	
04 8251 -2	1320.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043	
05 8251 -3	1320.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043	
06 8251 -4	1650.00	0.0562	0	CHRYSTOLITE	0	1	0.0042	17.79	0.0042	
07 8251 -5	1650.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 85% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 3

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ^{*/a}

24 hr⁺/a

CLIENT: NYC DEP

W&P FILE # 1079-01-02

CONTACT: MIKE PERAL

PROJECT: East Side Access

LABORATORY: ATC EUSCO

ANALYSIS METHOD: PCM TEM

circle one 7400 AHIERA EPA LEVEL II

LOCATION: 125th Ave

TECHNICIAN: George Barr Boron G.

8251

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cu.)
-01	Field Blank	1	—	—	—	1846	—	—	—	—
-02	Field Blank	1	—	—	—	1846	—	—	—	—
-03	Crew Room DECON	3	02	8.0	8.0	1845	2130	165	1320	—
-04	Exit 127 Fulton St	3	08	8.0	8.0	1846	2131	165	1320	—
-05	Street Int. 127 Fulton St	3	11	10.0	10.0	1848	2133	165	1650	—
-06	Street Int. 125 Fulton St	3	19	10.0	10.0	1850	2135	165	1650	—
-07	Exit 123 Fulton Street	3	21	10.0	10.0	1852	2137	165	1650	—
-08	CAPPED BLANK	1	—	—	—	—	—	—	—	—

COMMENTS:

SAMPLE BY: George Barr Boron DATE: 6/23/02

SIGNATURE: George Barr Boron Sunday

RELEASED BY: Boron GREG DATE: 6/23/02

SIGNATURE: Boron

RECEIVED BY: ATC DATE: 6/24/02

SIGNATURE: JD 7/2/02

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8251

Date: Monday, June 24, 2002

Client Project: NYC-DEP W & P File #: 1079.01.02
125 Fulton Street

Time: 12:00:57 PM

Comments:

Number of Pages: 3
(including cover page)