

**BENJAMIN KURZBAN
& SON CONTROL, INC.**1248 Ralph Ave.
BROOKLYN, N.Y. 11236

(718) 531-2900

INVOICE

1162

TO

Dept of Environmental Protection

59-17 Junction Blvd

Corona, NY 11368

DATE 9/11/02	ORDER NO.
SHIP TO Contract ROF-REM2	

SALESPERSON	DATE SHIPPED	SHIPPED VIA	F.O.B. POINT	TERMS	
QUANTITY	DESCRIPTION			UNIT PRICE	TOTAL
>	Registration # CT 82620020015280				
	Pin# 82602WTCROOF2				
	For work completed at 127 Fulton St				
	7287 SF @ 2/SF				
	Total Amount due this Invoice				\$14,574.00
	<i>R. R. R.</i>				

ORIGINAL

Thank You!

22. Sample Analysis Laboratory _____ 23. NYS DOH ELAP # _____

VI. PROJECT INFORMATION24. Starting date for this portion of work 08-22-02 Projected completion date 09-22-02Asbestos work schedule ☒ Monday ☒ Tuesday ☒ Wednesday ☒ Thursday ☒ Friday ☒ Saturday ☒ SundayShift from: 8⁰⁰ ☒ am ☐ pm to 8⁰⁰ ☐ am ☒ pmIf other,
specify _____

Access to inspect the premises must be provided during the work schedule indicated in this item.

25. Total amount of asbestos-containing material to be abated during this work

7287 Square Feet, and/or 0 Linear FeetACP 7
2/2001

134WTC
EMERGENCY
ONLY
PAPER
FORMS WILL BE
ACCEPTED



NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION
Asbestos Control Program
59-17 Junction Boulevard, 8th Floor, Corona, NY 11368-5107
ASBESTOS PROJECT NOTIFICATION
(ASBESTOS INSPECTION REPORT)

13354uoz
Building Dept. or TRU No
FOR OFFICIAL USE ONLY
1. NYCDEP
(See fee schedule)

When submitting this form at the NYC Department of Buildings, the original form and three (3) copies with original signatures are required. Submittal at the NYCDEP requires one copy of the form with original signatures. This form must be submitted to the NYC DEP not less than one week in advance of the start of abatement activities.

I. FACILITY

2. Address 127 Fulton St Borough Manhattan Zip 10038
AKA 42 Ann St, 3. Block 91 4. Lot 12
5. Type of Facility _____ 6. Name of Building _____

II. BUILDING OWNER

7. Name Collegiate Church Corp, 8. Contact Person DAVID RINNAR
9. Tel. # (212) 233-1960 Fax # _____
10. Address 45 JOHN STREET City NY State NY Zip 10038

III. GENERAL CONTRACTOR

11. Name _____ Tel. # _____

IV. ASBESTOS ABATEMENT CONTRACTOR

12. Name Benjamin Kurzban & Son Control 13. Contact Person Louie Iannico
14. Federal Employer ID. # PII 15. Tel. # (718) 531-2900 Fax # (718) 209-1808
16. Address 1248 Ralph Avenue City Brooklyn State NY Zip 11236

V. THIRD PARTY AIR MONITOR


17. Name Warren & Panzer ENGINEERS 18. Contact Person MICHAEL NOLAN
19. Federal Employer ID. # PII 20. Tel. # (212) 922-0077 Fax # (212) 922-0630
21. Address 228 East 45th St City New York State NY Zip 10017
22. Sample Analysis Laboratory _____ 23. NYS DOH ELAP # _____

VI. PROJECT INFORMATION

24. Starting date for this portion of work 08-22-02 Projected completion date 09-22-02
Asbestos work schedule ☒ Monday ☒ Tuesday ☒ Wednesday ☒ Thursday ☒ Friday ☒ Saturday ☒ Sunday
Shift from: 8⁰⁰ ☒ am ☐ pm to 8⁰⁰ ☐ am ☒ pm
If other, specify _____

Access to inspect the premises must be provided during the work schedule indicated in this item.

25. Total amount of asbestos-containing material to be abated during this work
7287 Square Feet, and/or 0 Linear Feet



ACP 7
2/2001

127 FULTON STREET

ASBESTOS INSPECTION REPORT (continued)26. Asbestos Hauler IESI, NY NYS DEC Permit # NJ-462 Tel.# (718) 522-2263Disposal Site(s) BlueRidge Landfill PO Box 399 Scotsdale, Pa 17254

27. This asbestos abatement is part of a (Item a through e requires filing of this form with NYC Department of Buildings)

- a) ☐ Demolition b) ☐ Boiler Replacement c) ☐ Sprinkler Replacement d) ☐ Renovation/Alteration
 e) ☐ Fireproofing Replacement f) ☒ Other (Describe) _____

28. TYPE OF ABATEMENT (Check all appropriate boxes)

- ☐ Removal ☐ Enclosure ☐ Encapsulation ☐ Repair ☒ Clean up

29. ABATEMENT PROCEDURE (Check all appropriate boxes)

- ☐ Full Containment ☐ Glovebag ☐ Tent ☐ DEP Variance Application

TRU 1335 Muz

30. LOCATIONS OF ABATEMENT ROOF MATERIAL : ROOF MEMBRANE (TAP)

Floor(s)	DESCRIBE SECTION OF FLOOR (e.g. entire, east wing, room #, boiler room, lobby, etc.)	AFFECTED SURFACES CONTAINING ACM (e.g. Pipe lagging, ceiling, plenum ducts, storage tanks, decking, etc.)	AMOUNT OF ACM		DESCRIPTION OF WORK BEING PERFORMED (e.g. running cable, installing fire sprinklers, removing and replacing boilers, etc.)
			SQUARE FEET	LINEAR FEET	
ROOF	BACK PORTION	ROOF SURFACES (ALL)	2500		ROOF, METAL, BULKHEADS
"	MIDDLE PORTION	PARTIAL ROOF	1187		BLACK SECTION (ALL) SILVER SECTION (PARTIAL) PARAPET TRASH CAN
"	FRONT PORTION	ROOF SURFACES	1500		FRONT SET BACK, DORMERS, DORMER FACADE SURFACES
FACADE	NORTH (ANN ST)	FIRE ESCAPES (7)	2100		

31. I hereby declare that the information provided herein is true and complete to the best of my knowledge. I am familiar with Federal, State and NYC laws and regulations applicable to asbestos related work.

<u>WARREN & PANZER ENGINEERS</u> Print Name of Air Monitor <u>[Signature]</u> Signature <u>07/16/02</u> Date	<u>B. KURZBAN & SON CONTROL</u> Print Name of Asbestos Contractor <u>[Signature]</u> Signature <u>07/16/02</u> Date	_____ Print Name of Applicant (if other than Owner) _____ Signature _____ Date
---	--	---

32. I understand that as the owner of a building where asbestos abatement activity occurs, I am responsible for the performance of the asbestos abatement activities in accordance with the Asbestos Control Program Rules. I have contracted the third party air monitor who is completely independent of all parties involved in the asbestos project. I hereby declare that I have authorized the filing of this notification for the work specified herein.

 Print Name of Owner

[Signature] NYC DEP
 Signature

07/16/02
 Date

A STAMPED COPY OF THIS FORM INCLUDING AMENDMENTS MUST BE AVAILABLE AT THE WORK SITE.

Any modification of information provided on this form must be reported immediately in writing directly to the NYC DEP ACP.

The requirements of the Asbestos Control Program Rules may not be lawfully avoided or lessened through the performance of work in incremental or piecemeal fashion.

ACP7
2/2001


ATHENICA

ENVIRONMENTAL SERVICES INC.

 Tel. (718) 784-7490
 Fax. (718) 784-4085

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

CLIENT: Warren & Panzer Engineers, P.C.

LABORATORY ID #: T02-08-132

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

 AVERAGE G.O. AREA (mm²): 0.012422

PROJECT: NYC DEP, 127 Fulton St.

DATE OF REPORT: 08/26/02

DATE OF ANALYSIS: 08/26/02

 EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (l)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIVITY (fug/m ³)	TOTAL ASBESTOS AIR CONC. (fug/m ³)	TOTAL ASBESTOS FILTER CONC. (fug/mm ²)	AIR CONC. FOR STRUCT. 0.5<S<5µm	AIR CONC. FOR STRUCT. S≥5.0µm	ASBEST. TYPE CHRVS.	AMPLIB. ASBEST. TYPE SPECIFY
01	T02-08-132-1899	On 6 th floor Hallway	1800	4	0.0497	0.0043	<0.0043	<20.13	NA	NA	NA	NA
02	T02-08-132-1900	On entrance to roof	1800	4	0.0497	0.0043	<0.0043	<20.13	NA	NA	NA	NA
03	T02-08-132-1901	On 5 th floor entrance	1800	4	0.0497	0.0043	<0.0043	<20.13	NA	NA	NA	NA
04	T02-08-132-1902	On roof back side right side	1800	4	0.0497	0.0043	<0.0043	<20.13	NA	NA	NA	NA
05	T02-08-132-1903	On roof back side left side	1800	4	0.0497	0.0043	<0.0043	<20.13	NA	NA	NA	NA

 ANALYST
 E. Dimitrakas

 LABORATORY DIRECTOR
 Spiro Dougaris

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a P.O.

W&P FILE #: 1679.01.01

LABORATORY:

ANALYSIS METHOD: PCM
circle one 7400 TEM
AHJERA EPA LEVEL II

TECHNICIAN: L JOTO

CONTACT:

CLIENT: NYCDOP

PROJECT: Roof

LOCATION: 127 Fulton

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (fib./cc.)
01	ON 6th FL. HALLWAY	J	01	10	10	11 15	14 15	180	1800	
02	ON ENTRANCE TO ROOF	J	02	10	10	11 18	14 18	180	1800	
03	ON 5th FL. ENTRANCE	J	03	10	10	11 21	14 21	180	1800	
04	ON ROOF BACKSIDE RIGHT SIDE	J	04	10	10	11 24	14 24	180	1800	
05	ON ROOF BACKSIDE LEFT SIDE	J	05	10	10	11 27	14 27	180	1800	
06	FIELD BLANK	1								
07	FIELD BLANK	1								
08	CAPPED BLANK	1								

SAMPLE BY: <u>Louis Joto</u>	DATE: <u>8-22-02</u>
SIGNATURE: <u>[Signature]</u>	
RELEASED BY: <u>Louis Joto</u>	DATE: <u>8-22-02</u>
SIGNATURE: <u>[Signature]</u>	
RECEIVED BY: <u>G. Sirota</u>	DATE: <u>8/26/02</u>
SIGNATURE: <u>[Signature]</u>	

702-08-132

SAMPLE TYPE CODES			
1 - Blank	5 - Final Clearance (inside)		
2 - Pre-Abatement	6 - Final Clearance (outside)		
3 - During Abatement	7 - Personal		
4 - During Glove Bag Removal	8 - Background		

SEE REVERSE SIDE FOR ANALYSIS INFORMATION


ATHENICA

ENVIRONMENTAL SERVICES INC.

 Tel. (718) 784-7400
 Fax. (718) 784-4085

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

 CLIENT: Warren & Panzer Engineers, P.C.
 LABORATORY ID #: T02-08-114
 ANALYT. METHODOLOGY: AHERA
 FILTER TYPE: M.C.B.
 AVERAGE G.O. AREA (mm²): 0.012422
 PROJECT: NYC DEP, 127 Fulton St.
 DATE OF REPORT: 08/23/02
 DATE OF ANALYSIS: 08/22/02
 EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (l)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIVITY (struct./cm ²)	TOTAL ASBESTOS AIR CONC. (struct./cm ²)	TOTAL ASBESTOS FILTER CONC. (struct./mm ²)	AIR CONC. FOR STRUCT. 0.55-5.0µm	AIR CONC. FOR STRUCT. 5.0-10µm	ASBEST. TYPE CHYRS.	AMPHIB. ASBEST. TYPE SPECIFY
01	T02-08-114-1792	5 th Floor Entrance	1800	4	0.0497	0.0043	<0.0043	<20.13	NA	NA	NA	NA
02	T02-08-114-1793	7 th Floor	1800	4	0.0497	0.0043	<0.0043	<20.13	NA	NA	NA	NA
03	T02-08-114-1794	Entrance to roof	1800	4	0.0497	0.0043	<0.0043	<20.13	NA	NA	NA	NA
04	T02-08-114-1795	South of roof	1800	4	0.0497	0.0043	<0.0043	<20.13	NA	NA	NA	NA
05	T02-08-114-1796	North of roof	1800	4	0.0497	0.0043	<0.0043	<20.13	NA	NA	NA	NA

 ANALYST
 E. Simulori

 LABORATORY DIRECTOR
 Spiro Dougaris

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc. did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to terms tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athena Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

**2228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630**

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

	24 hr ⁺ /a	12 hr ⁺ /a	6 hr ⁺ /a	3 hr ⁺ /a	Immediate ⁺ /a
--	-----------------------	-----------------------	----------------------	----------------------	---------------------------

W&P FILE #: 70-10-679

LABORATORY:

ANALYSIS METHOD: PCM

TEMP

ALBERTA EPA LEVEL II

TECHNICIAN: FST1 OSEWALD GIE

CONTACT:

TEMP

ALBERTA EPA LEVEL II

TECHNICIAN: FST1 OSEWALD GIE

SAMPLE NUMBER	SAMPLE DESCRIPTION & LOCATION	SAMPLE TYPE	PUMP #	FLOW RATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTRA- (lb./cc.)
01	BTH FLOOR ENTRANCE	3		4 4	1100 1830	450	1800	
02	7TH FLOOR	3		4 4	1102 1832	450	1800	
03	ENTRANCE TO ROOF	3		4 4	1104 1834	450	1800	
04	SOUTH OF ROOF	3		4 4	1106 1836	450	1800	
05	NORTH OF ROOF	3		4 4	1108 1838	450	1800	
06	BLANK							
07	"							
08	"							

COMMENTS:

SAMPLE BY: Festy Fernandez DATE: 08-21-02

SIGNATURE: F. Semboye DATE: 8-2-02

RELEASED BY: _____

SIGNATURE: _____
RECEIVED BY: A. C. JIGAL DATE: 8/22/02

SIGNATURE: _____

102-08-174

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION