NYC 9/11 Public Portal Document

Asbestos Inspection Report

Premise No. 127 FULTON STREET					Inspection Date: AS NOTED	
Floor ROOF	Zip 10038	Borough 1	Block 91	Lot 12	Squad # N/A	Badge # A020

Inspector Dennis Antzoulatos	Building Type COMMERCIAL	Basis of Inspection WTC Survey	Photos Taken Yes (No)
Contractor's Name Benjamin Kurzban & Son Control		Sample Number N/A	
Address City 1248 Ralph Avenue, Brooklyn		Sample Number N/A	
State Zip Phone NY 11236 (718)531-2900		Sample Number N/A	
Laboratory Name Warren & Panzer Engineers Inc.		Owner's Name	
Address City 228 East 45 Street New York		Address City	
State Zip Phone NY 10017 (212) 922-0077		State Zip Phone	
Contact Person		Time of Inspection from: AS NOTED	

TUESDAY AUGUST 20 2002

CONTRACTOR BRINGS EQUIPMENT TO THE JOBSITE.

WEDNESDAY AUGUST 21 2002 (800AM - 800PM)

THE CLEAN UP OF THE ROOF BEGINS. DUE TO SPACE LIMITATIONS, A REMOTE DECONTAMINATION UNIT WILL NOT BE USED. STEP OFF PADS WILL BE UTILIZED INSTEAD. WORKERS WILL DOUBLE SUIT, ALL STAIR CASE LANDINGS FROM THE 5TH FLOOR TO THE ROOF WILL BE PLASTICIZED. WORKERS WILL TAKE ELEVATOR TO THE 5TH FLOOR AND WALK THE REST OF THE WAY TO THE ROOF. WASTE BAGS WILL BE TAKEN OUT OF THE BUILDING USING THIS ROUTE. AIR MONITORING FOR THIS PORTION OF THE PROJECT WAS PERFORMED BY FESTY OSEMWEGIE (CERTIFICATE # AH 01-01030 EXP 01/03) OF WARREN & PANZER.

THURSDAY AUGUST 22 2002 (800AM - 800PM)

THE CLEAN UP OF THE ROOF AREA IS COMPLETED TODAY. AIR MONITORING FOR THIS PORTION OF THE CLEAN UP PROJECT WAS PERFORMED BY LUIS SOTO (CERTIFICATE # AH 00-20894 EXP 03/03). I CONDUCTED A VISUAL INSPECTION OF THE CLEANED ROOF SURFACES AND OBSERVED NO VISIBLE WTC DEBRIS. THE CLEAN UP PROJECT AT THIS PREMISE IS NOW COMPLETE

RL.

NYC-WTC_000127939