

Asbestos Inspection Report

Premise No. 44 GOLD STREET					Inspection Date: 09-27-02	
Floor ROOF	Zip 10038	Borough 1	Block 76	Lot 25	Squad # N/A	Badge # A020
Inspector Dennis Antzoulatos		Building Type COMMERCIAL		Basis of Inspection WTC Survey		Photos Taken Yes/ (No)
Contractor's Name Benjamin Kurzban & Son Control				Sample Number N/A		
Address City 1248 Ralph Avenue, Brooklyn				Sample Number N/A		
State Zip Phone NY 11236 (718)531-2900				Sample Number N/A		
Laboratory Name Warren & Panzer Engineers Inc.				Owner's Name		
Address City 228 East 45 Street New York				Address City		
State Zip Phone NY 10017 (212) 922-0077				State Zip Phone		
Contact Person				Time of Inspection from: N/A		

FRIDAY SEPTEMBER 27 2002

THE CLEAN UP OF THE ROOF OF THE PREMISE WAS CONDUCTED TODAY. AIR SAMPLING FOR THE CLEAN UP PROJECT WAS PERFORMED BY ARTHUR C. JETTER (CERTIFICATE # AH 97-06135 EXP 03/03) OF WARREN & PANZER. AFTER THE CLEAN UP ACTIVITIES WERE COMPLETED, I CONDUCTED A VISUAL INSPECTION OF THE CLEANED ROOF SURFACES AND OBSERVED NO VISIBLE WTC DEBRIS. THE CLEAN UP PROJECT AT THE PREMISE IS NOW COMPLETE.

22