NYC 9/11 Public Portal Document

ATC Associates
104 East 25 Street, New York, NY 10010
Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Fabio Pedone
Warren & Panzer Engineers , P.C.
228 E. 45th Street
New York NY 10017
Fax: (212) 922-0630 Phone: (212) 922-0077
Project: NYC-DEP W & P File #: 1079.01.02
67 Greenwick

Received: 7/1/02 9:00:00 AM
ATC Group #: 8365
Analysis Date: 7/1/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5	# Structures 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
JB63002-9 8365 -1	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046	
JB63002-1 8365 -2	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046	
JB63002-1 8365 -3	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046	
JB63002-1 8365 -4	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046	
JB63002-1 8365 -5	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046	

ROMAN PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101167-0, NY State ELAP #10879

34

NYC-WTC_000128290

NYC-WTC_000128291

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr+/a 12 hr+/a 6 hr+/a 3 hr+/a Immediate +/a

P.O. _____

CLIENT: NYCDEP
PROJECT: 67 Greenwich
LOCATION: Front Facade
8365

W&P FILE #: 1079.01-02
LABORATORY:
ANALYSIS METHOD: PCM (TEM 7400) TEM AHERA TEM EPA LEVEL II
circle one
TECHNICIAN: John Boyd

CONTACT: Mike Ndan

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (fib./cc.)
JB63092-9	Inn Left Side	TEM		10	10	1400	1630	150	1500	
JB63092-10	Inn Left Front	TEM		10	11	1402	1632	150	1500	
JB63092-11	Inn Right Front	TEM		10	10	1404	1634	150	1500	
JB63092-12	Inn Right Side	TEM		10	10	1406	1636	150	1500	
JB63092-13	By Decon	TEM		10	10	1408	1638	150	1500	
JB63092-14	Field Blank	N A		N A	N A	0	0	0	0	
JB63092-15	" "	N A		N A	N A	0	0	0		
JB63092-16	Sealed Blank	N A		N A	N A	0	0	0	0	
35										

COMMENTS:

SAMPLE BY:	John Boyd	DATE: 6.30.02
SIGNATURE:	John Boyd	
RELEASED BY:	John Boyd	DATE: 6.30.02
SIGNATURE:	John Boyd	
RECEIVED BY:	ATC	DATE: 7/01/02
SIGNATURE:		9 am

SAMPLE TYPE CODES

1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

NYC 9/11 Public Portal Document

NYC 9/11 Public Portal Document

ATC Associates Inc.
104 East 25 Street
New York, NY 10010
TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers , P.C.

Fax #: (212) 922-0630

Date: Monday, July 01, 2002

Time: 3:49:36 PM

Comments:

From: ROMAN PEYSAKHOV

ATC Group #: 8365

Client Project: NYC-DEP W & P File #: 1079.01.02
67 Greenwich

Number of Pages: 3
(including cover page)

33