

TEL :

Dec 31.00

15:28 No.002 P.11

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel: (718) 794-7400

Fax: (718) 794-4065

CLIENT: Warren & Panzer Engineers, P.C.

LABORATORY ID #: T02-11-040

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

AVERAGE G.O. AREA (mm²): 0.013433

PROJECT: NYC DEP, 94 Greenwich Street

DATE OF REPORT: 11/08/02

DATE OF ANALYSIS: 11/08/02

EFFECTIVE FILTER AREA (mm²): 385**LABORATORY RESULTS**

CLIENT #	LAB. ID #	LOCATION	VOLUME (ft ³)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIV. (struck/cm ²)	TOTAL ASBESTOS AIR CONC. (struck/cm ²)	TOTAL ASBESTOS FILTER CONC. (struck/cm ²)	AIR CONC. FOR STRUCT. 0.555-0.1um	AIR CONC. FOR STRUCT. 0.555-0.1um	ASBEST. TYPE CHRY.	ASBEST. TYPE SPECIFY
01	T02-11-040-3906	Inside work area south	1575	4	0.0537	0.0045	<0.0045	<18.61	NA	NA	NA	NA
02	T02-11-040-3907	Inside work area east	1575	4	0.0537	0.0045	<0.0045	<18.61	NA	NA	NA	NA
03	T02-11-040-3908	Inside work area west	1575	4	0.0537	0.0045	<0.0045	<18.61	NA	NA	NA	NA
04	T02-11-040-3909	Inside work area center	1575	4	0.0537	0.0045	0.0091	37.22	0.0091	<0.0045	Chrys.	NA
05	T02-11-040-3910	Inside work area north	1575	4	0.0537	0.0045	0.0182	74.44	0.0091	0.0091	Chrys.	NA

ANALYST
E. SioukriLABORATORY DIRECTOR
Spiro Dongaris

LABORATORY CERTIFICATION NUMBERS: NVLAP 101938, ELAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- This report retains only in boxes tested. This report must not be used to claim product enforcement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

