

10/23/2002 15:24 FAX

4028

**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel. (718) 784-7490
Fax. (718) 784-4835**AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY**

CLIENT: Warren & Parzer Engineers, P.C.

LABORATORY ID #: T02-10-134

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

AVERAGE G.O. AREA (mm²): 0.013838

PROJECT: NYC DEP, 94 Greenwich Street

DATE OF REPORT: 10/21/02

DATE OF ANALYSIS: 10/21/02

EFFECTIVE FILTER AREA (mm²): 385**LABORATORY RESULTS**

CLIENT #	LAB. ID #	LOCATION	VOLUME (ft)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIV. (strand/cm ²)	TOTAL ASBESTOS AIR CONC. (strand/cm ²)	TOTAL ASBESTOS FILTER CONC. (str./mm ²)	AIR CONC. FOR STRUCT. 0.55-5µm	AIR CONC. FOR STRUCT. ≥5.0µm	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
01	T02-10-134-3359	Ground level 94 Greenwich	1800	4	0.0554	0.0039	<0.0039	<18.07	NA	NA	NA	NA
02	T02-10-134-3360	Ground level 94 Greenwich	1800	4	0.0554	0.0039	<0.0039	<18.07	NA	NA	NA	NA
03	T02-10-134-3361	On roof building adjacent 94 Greenwich	1800	4	0.0554	0.0039	<0.0039	<18.07	NA	NA	NA	NA
04	T02-10-134-3362	On roof building adjacent 94 Greenwich	1800	4	0.0554	0.0039	<0.0039	<18.07	NA	NA	NA	NA
05	T02-10-134-3363	On roof building adjacent 94 Greenwich	1800	4	0.0554	0.0039	<0.0039	<18.07	NA	NA	NA	NA

ANALYST
E. Dimitrakas

LABORATORY DIRECTOR
Spiro Dongaris**LABORATORY CERTIFICATION NUMBERS: NYLAP 101958, ELAP 10955**

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling certificates will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported asbestos concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NYLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.