

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

T020724G

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O.

CLIENT: NYC DEP

W&P FILE #:

LABORATORY:

ANALYSIS METHOD:

TECHNICIAN:

RECEIVED

PROJECT: 104 Fulton

circle one

PCM

TECHNICIAN

2007 JUL 24 11:52

CONTACT: Mike Nolan

LOCATION: Fuade

7400

AUEBA EPA LEVEL II

TECHNICIAN:

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
1072301 01	Near Train station	3		4	4	0942	1720	450	1800	
1072301 02	right side of building	3		4	4	0942	1722	450	1800	
1072301 03	Left side of building	3		4	4	0944	1724	480	1800	
1072301 04	by east door (left)	3		4	4	0945	1725	450	1800	
1072301 05	by east door (right)	3		4	4	0946	1726	450	1800	
1072301 06	Field Blank	1		NA	NA					
1072301 07	" "	1		NA	NA					
1072301 08	Sealed Blank	1		NA	NA					

COMMENTS:

SAMPLE BY: <u>John Boyd</u>	DATE: <u>7-23-07</u>
SIGNATURE: <u>[Signature]</u>	
RELEASED BY: <u>John Boyd</u>	DATE: <u>7-23-07</u>
SIGNATURE: <u>[Signature]</u>	
RECEIVED BY: <u>D. OREN</u>	DATE: <u>7/24/07</u>
SIGNATURE: <u>[Signature]</u>	

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

ANALYSIS REPORT ASBESTOS IN AIR Transpiration Electrode Method

CLIENT: WARREN & PANZER
PROJECT: 104 Fulton - Fucade

Lab ID#	Client Sample ID#	Sample Location	Volume (liters)	Filter Area (mm ²)	Analytical Sensitivity (struc/cc air)	Asbestos Type(s)	Asbestos Structures (microns)	Detectable	Structure Density (structure/m ³)	Structure Concentration (struc/cc) Total
T-01	08-02-01		1800	385	0.0043	ND	0	0	0	0.0043
T-02	08-02-02									
T-03	08-02-03									
T-04	08-02-04									
T-05	08-02-05									
T-06										
T-07										
T-08										
T-09										
T-10										

Date Received: 7/24/02
Date Analyzed: 7/25/02
Date of Report: 7/25/02

Area Analyzed: 0.050 0 mm²
Grid Opening Area: 0.007575 mm² - 0.0100
Date Collected: 7/23/02

Analyst: David Chen
Lab Director: George Kouravos

Analysis performed according to AHERA Method (EPA 40 CFR Part 763 - Appendix A). Samples will be stored for thirty (30) days and then returned to the client upon request.

AHERA #: 100769
NYS-IRON ELAP#: 11273
NIST-NVLA# #: 802037