

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02

111 Fulton Street

Received: 7/19/02

11:30:00 AM

ATC Group #: 8543

Analysis Date: 7/19/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8543 -1	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
02 8543 -2	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
03 8543 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
04 8543 -4	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
05 8543 -5	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

228 East 45th Street
New York, NY 10017
(212) 922-8977
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE OF

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O. CLIENT: NYC DEPW&P FILE #: 1079-01-02PROJECT: ROOFLABORATORY: ATCCONTACT: LOCATION: 111 FULTONANALYSIS METHOD: PCM TEMP TEMP
circle one 7400 AHERA EPA LEVEL IITECHNICIAN: Peggy O'Sullivan

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
01	BLANK	1								
02	"	1								
03	Below	3								
04	East TD Roof	3		3	3	0830	1830	600	1800	
05	East Side of Roof	3		3	3	0832	1832	600	1800	
06	West " " "	3		3	3	0834	1834	600	1800	
07	South " " "	3		3	3	0836	1836	600	1800	
08	BLANK	1		3	3	0838	1838	600	1800	

COMMENTS:

SAMPLE BY: Peggy O'Sullivan DATE: 7-18-02
SIGNATURE: P
RELEASED BY: Peggy O'Sullivan DATE: 7-18-02
SIGNATURE: o
RECEIVED BY: ATC
SIGNATURE: JP 11:30am

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8543

Date: Friday, July 19, 2002

Client Project: NYC DEP. W&P# 1079.01.02
111 Fulton Street

Time: 4:07:26 PM

Comments:

Number of Pages: 3
(including cover page)