

TESTWELL LABORATORIES, INC.
ENVIRONMENTAL DIVISION

PAGE 1 OF 1

DATE: 7/30/02

ASBESTOS LABORATORY

TEM AIR SUMMARY SHEET

CLIENT: **Warren & Panzer**PROJECT: NYC Dep/ Roof & FacadesMETHOD: AHERA

CLIENT NUMBER	LAB # 01 TEM -	VOLUME COLLECTED (L)	GRID OPENINGS ANALYZED	GRID AREA ANALYZED (mm ²)	COUNTABLE ASBESTOS STRUCTURES PER SAMPLE	CONCENTRATION (Structures/mm ²)	CONCENTRATION (Structures/cc)
001	5221	1800.0	4	0.048	0	< 20.66	< 0.004
002	5222	1800.0	4	0.048	0	< 20.66	< 0.004
003	5223	1800.0	4	0.048	0	< 20.66	< 0.004
004	5224	1800.0	4	0.048	0	< 20.66	< 0.004
005	5225	1800.0	4	0.048	0	< 20.66	< 0.004

	Structures/mm ²	Structures/cc
TOTAL AVERAGE CONCENTRATIONS	< 20.66	< 0.004

NOTE: When no asbestos structures are counted, the Analytical Sensitivity Detection Limit is reported.

COMMENTS: _____

ANALYST'S SIGNATURE: 