NYC 9/11 Public Portal Document

ATC Associates
104 East 25 Street, New York, NY 10010
Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017
Fax: (212) 922-0630 **Phone:** (212) 922-0077
Project: NYC-DEP W & P File #: 1079.01.02
114 Fulton Street

Received: 6/25/02 6:00:00 PM
ATC Group #: 8282
Analysis Date: 6/26/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5μ-5	# Structures 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
01 8282 -1	1524.00	0.0562	0	None Detected	0	0	0.0045	<17.79	<0.0045	
02 8282 -2	1512.00	0.0562	0	None Detected	0	0	0.0045	<17.79	<0.0045	
03 8282 -3	1512.00	0.0562	0	None Detected	0	0	0.0045	<17.79	<0.0045	
04 8282 -4	1512.00	0.0562	0	None Detected	0	0	0.0045	<17.79	<0.0045	
05 8282 -5	1512.00	0.0562	0	None Detected	0	0	0.0045	<17.79	<0.0045	

MARK PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10878

5

NYC-WTC_000128825

NYC 9/11 Public Portal Document

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

P.O. _____

WARREN & PANZER ENGINEERS, P.C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

CLIENT: DEP 8282
PROJECT: BUILDING FACADE + ROOF CLEANING
LOCATION: 114/116 FULTON STREET

W&P FILE #: 1079 01-02
TURN AROUND: 24
TECHNICIAN: J Burgess

Analysis Method: PCM - 7400
(circle one) (TEM - AHERA)
TEM - EPA LEVEL II

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (fib./cc.)
01	ROOF ENTRY	3		4	4	0810	1495	381	1524	
02	WEST SIDE REAR 116 BET 114			4	4	0814	1447	378	1512	
03	114 EAST SIDE DUTCH ST			4	4	0816	1448	378	1512	
04	114 WEST SIDE			4	4	0818	1449	378	1512	
05	WEST SIDE 116 - FACE/FULTON ST	3		4	4	0820	1450	378	1512	
06	FIELD BLANK									
07	FIELD BLANK									

SAMPLED BY: John W Burgess DATE: 06-25
SIGNATURE: John W Burgess
RELEASED BY: John W Burgess DATE: 06-25
SIGNATURE: John Burgess
RECEIVED BY: [illegible] DATE: 6/25
SIGNATURE: [illegible]

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

NYC-WTC_000128826

NYC 9/11 Public Portal Document

ATC Associates Inc.
104 East 25 Street
New York, NY 10010
TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

Fax #: (212) 922-0630

Date: Wednesday, June 26, 2002

Time: 1:56:49 AM

Comments:

From: MARK PEYSAKHOV

ATC Group #: 8282

Client Project: NYC-DEP W & P File #: 1079.01.02
114 Fulton Street

Number of Pages: 3
(including cover page)

4