

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEF W & P File #: 1079.01.02

114-116 Fulton Street, Back Façade

Received: 6/28/02

7:30:00 PM

ATC Group #: 8326

Analysis Date: 6/29/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures 0.5µm-5µm	Analytical Sensitivity (f/cc)	Asbestos Concentration (f/mm ³)	Notes
03 8326 -1	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048
04 8326 -2	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048
05 8326 -3	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048
06 8326 -4	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048
07 8326 -5	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10675

38

Page 1 of 1

**228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630**

8326

P.O.

WARREN & PANZER ENGINEERS, P.C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

CLIENT: NYC DFP

PROJECT: 16-16-fulgdn 51
LOCATION: 6342 E 170th Ave

WSP FILE #: 1079-01-02

TURN AROUND: 20440

TECHNICIAN: F-881-088ms E288

Analysis Method: **PCM - 7400**
(circle one) ~~TEM - ABERA~~
TEM - EPA LEVEL II

SAMPLE # NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
01	BLANK	1	-	-	-	-	-	-
02	" "	1	-	-	-	-	-	-
03		3		3	1800	480	1440	
04		3		3	1802	480	1440	
05		3		3	1804	480	1440	
06		3		3	1806	480	1440	
07		3		3	1808	480	1440	
08	BLANK	+	-	-	-	-	-	-

SAMPLED BY:	CE817 OJ2mwE91E	DATE: 06-28-02
SIGNATURE:		
RELEASED BY:	CE817 OJ2mwE91E	DATE: 06-28-02
SIGNATURE:		
RECEIVED BY:		DATE: 06/28/02
SIGNATURE:	H. Gray	

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8326

Date: Saturday, June 29, 2002

Client Project: NYC-DEP W & 2 File #: 1079.01.02
114-116 Fulton Street, Back Facade

Time: 12:47:12 PM

Comments:

Number of Pages: 3
(including cover page)

37