

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017

Received: 6/24/02 7:00:00 AM
ATC Group #: 8252
Analysis Date: 6/24/02

Fax: (212) 922-0630 Phone: (212) 922-0077
Project: NYC-DEP W & P File #: 1079.01.02
114-116,118,120,122 Fulton Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8252 -1	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
02 8252 -2	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
03 8252 -3	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
04 8252 -4	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
05 8252 -5	1440.00	0.0562	0	CHRYSTOLE	0	1	0.0048	17.79	0.0048

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 1

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

P.O. _____

WARREN & PANZER ENGINEERS, P.C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

CLIENT: NYC DEP 8252
PROJECT: 114-116, 118, 120, 122 Fulton St
LOCATION: Facades cleaning

W&P FILE #: 1079.01.02
TURN AROUND: 24 hour
TECHNICIAN: Greg Boron

Analysis Method: PCM - 7400
(circle one) TEM - AHERA
TEM - EPA LEVEL II

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE		TIME		TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
				START	STOP	ON	OFF			
01	Street by mobile decon	3	03	4	4	10:45	16:45	360	1440	
02	Street at work area	3	14	4	4	10:47	16:47	360	1440	
03	Street at work area	3	18	4	4	10:49	16:49	360	1440	
04	Street at work area	3	N/A	4	4	10:51	16:51	360	1440	
05	Street at work area	3	113	4	4	10:53	16:53	360	1440	
06	Field Blank	1								
07	Field Blank	1								
08	Blank	1								

SAMPLED BY: <u>GREG BORON</u>	DATE: <u>6/23/02</u>
SIGNATURE: <u>Greg Boron</u>	
RELEASED BY: <u>GREG BORON</u>	DATE: <u>6/23/02</u>
SIGNATURE: <u>Greg Boron</u>	
RECEIVED BY: <u>ATC</u>	DATE: <u>6/24/02</u>
SIGNATURE: <u>JP</u>	<u>Tam</u>

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Podenc
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

ATC Group #: 8252

Fax #: (212) 922-0630

Client Project: NYC-DEP W & P File #: 1079.01.02
114-116, 118, 120, 122 Fulton Street

Date: Monday, June 24, 2002

Time: 12:01:09 PM

Comments:

Number of Pages:

3
(including cover page)