

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

114 Fulton Street

Received: 6/25/02

6:00:00 PM

ATC Group #: 8282

Analysis Date: 6/26/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8282 -1	1524.00	0.0562	0	None Detected	0	0	0.0045	<17.79	<0.0045
02 8282 -2	1512.00	0.0562	0	None Detected	0	0	0.0045	<17.79	<0.0045
03 8282 -3	1512.00	0.0562	0	None Detected	0	0	0.0045	<17.79	<0.0045
04 8282 -4	1512.00	0.0562	0	None Detected	0	0	0.0045	<17.79	<0.0045
05 8282 -5	1512.00	0.0562	0	None Detected	0	0	0.0045	<17.79	<0.0045

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-D, NY State ELAP #10879

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

P.O. _____

WARREN & PANZER ENGINEERS, P.C. AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

CLIENT: DEP 8782
PROJECT: BUILTUP FACADE + ROOF CLEANUP
LOCATION: 114 116 FULTON STREET

W&P FILE #: 1079 01-02
TURN AROUND: 24
TECHNICIAN: J Burgess

Analysis Method: PCM - 7400
(circle one) TEM - AHERA
TEM - EPA LEVEL II

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE		TIME		TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cu.)
				START	STOP	ON	OFF			
01	ROOF ENTRY	3		4	4	0810	1445	381	1524	
02	WEST SIDE FACADE 116 RDY 114	↑↑		4	4	0814	1447	378	1512	
03	114 EAST SIDE DUTCH ST	↑↑		4	4	0816	1448	378	1512	
04	114 WEST SIDE	↓↓		4	4	0818	1449	378	1512	
05	WEST SIDE 116 - FACADE FULTON ST	3		4	4	0820	1450	378	1512	
06	FIELD BLANK									
07	FIELD BLANK									

SAMPLED BY: John H. Burgess DATE: 06-25
SIGNATURE: [Signature]
RELEASED BY: John H. Burgess DATE: 06-25
SIGNATURE: [Signature]
RECEIVED BY: [Signature] DATE: 6/25
SIGNATURE: [Signature]

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8282

Date: Wednesday, June 26, 2002

Client Project: NYC-DEP W & P File #: 1079.01.02
114 Fulton Street

Time: 1:56:49 AM

Comments:

Number of Pages: 3
(including cover page)

4