

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

114-116 Fulton Street

Received: 6/28/02

6:00:00 PM

ATC Group #: 8330

Analysis Date: 6/29/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
03 8330 -1	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049
04 8330 -2	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049
05 8330 -3	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049
06 8330 -4	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049
07 8330 -5	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLUWTEM #101187-0, NY State ELAP #10879

220 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0539

8330

WARREN & PANZER ENGINEERS, P. C. AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE ____ OF ____

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O. _____

CLIENT: NYCDEP
PROJECT: 114-116 FULTON ST
LOCATION: ROOF

W&P FILE #: 1079-01-02
LABORATORY: ATC
ANALYSIS METHOD: PCM TEM TEM
circle one 7400 AHERA EPA LEVEL II
TECHNICIAN: FESTY OSEMIWELNE

CONTACT: _____

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
01	BLANK	1						
02	"	1						
03	EAST SIDE OF ROOF	5		10 10	0730 0950	140	1400	
04	WEST " " "	5		10 10	0732 0952	140	1400	
05	SOUTH " " EXIT	6		10 10	0734 0954	140	1400	
06	NORTH " " EXIT	6		10 10	0736 0956	140	1400	
07	UNDER THE SCAFFOLD	6		10 10	0738 0958	140	1400	
08	BLANK							

COMMENTS:

SAMPLE BY: FESTY OSEMIWELNE DATE: 06/28/02
SIGNATURE: [Signature]
RELEASED BY: FESTY OSEMIWELNE DATE: 06/28/02
SIGNATURE: [Signature]
RECEIVED BY: _____ DATE: 06/28/02
SIGNATURE: H. Gray

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8330

Date: Saturday, June 29, 2002

Client Project: NYC-DEP W & P File #: 1079.01.02
114-116 Fulton Street

Time: 12:53:54 PM

Comments:

Number of Pages: 3
(including cover page)

19