

JUL-02-2002 14:28

NYC D.E.P. PUBLIC AFFAIRS

P.03/04

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

Setbacks, 114-116 Fulton Street

Received: 7/1/02

8:00:00 PM

ATC Group #: 8372

Analysis Date: 7/2/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 2.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	Notes
01 8372 -1	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048
02 8372 -2	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048
03 8372 -3	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048
04 8373 -4	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048
05 8372 -5	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101167-0, NY State ELAP #10879

Page 1 of 1

JUL-02-2002 13:01

P.02

228 East 45th Street
New York, NY 10017
(212) 922-0077
For (212) 922-0030

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

P.O.

W&P FILE #: 1079.01.02

CONTACT:

CLIENT: NYCDEP

PROJECT: Setbacks

LOCATION: 114-116 FULTON ST.

LABORATORY: **ATC**

ANALYSIS METHOD: PCM
circle one 7400

TEM TEM
HERA ERA LEVEL II

TECHNICIAN: L. SOTO

[illegible]

COMMENTS:

SAMPLE BY: <u>Louis Soto</u>	DATE: <u>7-1-02</u>
SIGNATURE: <u>[Signature]</u>	
RELEASED BY: <u>Louis Soto</u>	DATE: <u>7-1-02</u>
SIGNATURE: <u>[Signature]</u>	
RECEIVED BY: <u>R PENDAKHOL</u>	DATE: <u>7.1.02</u>
SIGNATURE: <u>Rkey</u>	<u>20:00</u>

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

TOTAL P.04

JUL-02-2002 14:29

NYC D.E.P. PUBLIC AFFAIRS

P.04/04

FAX TRANSMISSION

NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION BUREAU OF PUBLIC AFFAIRS

59-17 JUNCTION BLVD
CORONA, NY 11368
19TH FLOOR

TEL: (718) 595-6600
FAX: (718) 595-3477

Date: 7/2/02

To: K High

Fax #: 3744

From: **GEOFFREY RYAN**
Acting Director

Subject: Asbestos report

of Page 4

COMMENTS: This came to our FAX machine,
but I think it is for you.

JUL-02-2002 14:28

NYC D.E.P. PUBLIC AFFAIRS

P.02/04

**ATC Associates Inc.**

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION**To:** Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.**From:** MARK PEYSAKHOV**Fax #:** (212) 922-0630**ATC Group #:** 8372**Date:** Tuesday, July 02, 2002**Client Project:** NYC-DEP W & P File #: 1079.01.02
Setbacks, 114-116 Fulton Street**Time:** 12:16:50 PM**Number of Pages:**3
(including cover page)**Comments:**

JUL-02-2002 13:00

99%

P.01