

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

122 Fulton Street

Received: 6/21/02

7:30:00 PM

ATC Group #: 8215

Analysis Date: 6/22/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
JB62102-1 8215 -1	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046
JB62102-2 8215 -2	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046
JB62102-3 8215 -3	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046
JB62102-4 8215 -4	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046
JB62102-5 8215 -5	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8215

Date: Saturday, June 22, 2002

Client Project: NYC-DEP W & P File #: 1079.01.02
122 Fulton Street

Time: 5:38:54 AM

Number of Pages: 3
(including cover page)

Comments:

