

Asbestos Inspection Report

Premise No. 64 FULTON STREET					Inspection Date: 11-16-02	
Floor 2nd	Zip 10038	Borough 1	Block 76	Lot 1	Squad # N/A	Badge # A020
Inspector Dennis Antzoulatos		Building Type MIXED USE		Basis of Inspection BWTC EPA Referral		Photos Taken (Yes/No)
Contractor's Name N/A				Sample Number N/A		
Address City				Sample Number N/A		
State Zip Phone				Sample Number N/A		
Laboratory Name N/A				Owner's Name		
Address City				Address City		
State Zip Phone				State Zip Phone		
Contact Person				Time of Inspection from: 0710AM - 0720AM		
SATURDAY NOVEMBER 16 2002 AT THE REQUEST OF ACP DEPUTY DIRECTOR PENNY THEODORELLYS, I CONDUCTED AN INSPECTION OF THE INPLACE PIPE INSULATION IN APT. 900. THIS WAS A REFERRAL FROM USEPA. THE INPLACE PIPE INSULATION HAS BEEN THOROUGHLY WRAPPED WITH RED AND GREY DUCT TAPE. NO PIPE INSULATING MATERIAL IS EXPOSED. THE ENDS OF THE INSULATION HAVE ALSO BEEN THOROUGHLY SEALED. NO VISIBLE DUST OR INSULATION MATERIAL FRAGMENTS WERE OBSERVED ON THE FLOOR OR OTHER HORIZONTAL SURFACES. THE RESULTS OF THIS INSPECTION WERE FORWARDED TO ACP DIRECTOR P. THEODORELLYS FOR FURTHER ACTION.						

