

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E 45th Street
New York NY 10017

Received: 6/24/02 10:00:00 PM
ATC Group #: 8271
Analysis Date: 6/25/02

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02
15 / 7172 Dutch

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
JB62402-1 8271 -1	1680.00	0.0562	0	None Detected	0	0	0.0041	<17.79	<0.0041
JB62402-2 8271 -2	1680.00	0.0562	0	None Detected	0	0	0.0041	<17.79	<0.0041
JB62402-3 8271 -3	1680.00	0.0562	0	None Detected	0	0	0.0041	<17.79	<0.0041
JB62402-4 8271 -4	1680.00	0.0562	0	None Detected	0	0	0.0041	<17.79	<0.0041
JB62402-5 8271 -5	1680.00	0.0562	0	None Detected	0	0	0.0041	<17.79	<0.0041

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

24

8271

Q.

WARREN & PANZER ENGINEERS, P.C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

CLIENT: NYC DRR
PROJECT: 15/173 Dutch
LOCATION: Plot on 13 Dutch

Analysis Method: PCM-7400
(circle one)
TEM - AHERA
TEM - EPA LEVEL II

SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	SAMPLE TYPE	PUMP #	FLOW RATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME CONCENTRATION (ml/min)
J862402-1	IWA Right side	TEM		4 4	1145 1745	420	1680
J862402-2	IWA Left Side	TEM		4 4	1147 1747	420	1680
J862402-3	Bx Decon	TEM		4 4	1149 1749	420	1680
J862402-4	Inside Door	TEM		4 4	1151 1751	420	1680
J862402-5	In the 6 th floor	TEM		4 4	1153 1753	420	1680
J862402-6	Field Blank	N/A		N/A N/A	0 0	0	
J862402-7	" " "	N/A		N/A N/A	0 0	0	
J862402-8	Sealed Blank	N/A		N/A N/A	0 0	0	

SAMPLED BY:	John Boyd	DATE:	6-24-92
SIGNATURE:	<i>John Boyd</i>		
RELEASED BY:	John Boyd	DATE:	6-24-92
SIGNATURE:	<i>John Boyd</i>		
RECEIVED BY:		DATE:	
SIGNATURE:			

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

Fax #: (212) 922-0630

Date: Tuesday, June 25, 2002

Time: 1:50:45 AM

Comments:

From: ROMAN PEYSAKHOV

ATC Group #: 3271

Client Project: NYC-DEP W & P File #: 1079.01.02
15 / 7172 Dutch

Number of Pages:

3
(including cover page)

23