

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

CLIENT: Warren & Panzer Engineers, P.C.
LABORATORY ID #: T02-09-004
ANALYT. METHODOLOGY: AHERA
FILTER TYPE: M.C.E.
AVERAGE G.O. AREA (mm²): 0.912422

PROJECT: NYC DEP, 40 Exchange Pl.
DATE OF REPORT: 09/05/02
DATE OF ANALYSIS: 09/05/02
EFFECTIVE FILTER AREA (mm²): 385



ATHENICA

ENVIRONMENTAL SERVICES, INC.

Tel. (718) 784-7490
Fax. (718) 784-4083

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (L)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIV. (atracul/cm ³)	TOTAL ASBESTOS AIR CONC. (atracul/cm ³)	TOTAL ASBESTOS FILTER CONC. (sh-/mm ³)	AIR CONC. FOR STRUCT. 0.5<=d<5µm	AIR CONC. FOR STRUCT. >5.0µm	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST TYPE SPECIFY
001	T02-09-004-2083	N side of the roof (W)	1305	5	0.0621	0.0047	<0.0047	<16.10	NA	NA	NA	NA
002	T02-09-004-2084	N side of the roof (SW)	1305	5	0.0621	0.0047	<0.0047	<16.10	NA	NA	NA	NA
003	T02-09-004-2085	S side of the roof (E)	1305	5	0.0621	0.0047	<0.0047	<16.10	NA	NA	NA	NA
004	T02-09-004-2086	S side of the roof (Mid)	1305	5	0.0621	0.0047	<0.0047	<16.10	NA	NA	NA	NA
005	T02-09-004-2087	Roof entrance	1305	5	0.0621	0.0047	<0.0047	<16.10	NA	NA	NA	NA

6.5.10

ANALYST
E. Sioukri

LABORATORY DIRECTOR
Suing Doctors

LABORATORY CERTIFICATION NUMBERS: NYLAF 101958, ELAP 10955

- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a two duplicate analysis. If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Aditex Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

**220 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0639**

20

WARREN & PANZER ENGINEERS, P.C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

CLIENT: **DEEP**

CLIENT: 8 E P
PROJECT: 40 Exchange Pl

CLIENT: SEI
PROJECT: 40 Exchange Pl.
LOCATION: Wardens (Bates Bldg)

W&P FILE # 11078 01 09

TUEN ABOND. 84724

TECHNICIAN. 57-1022-1

Analysis/Method: PCM - 7400

(circle one) TEM -- ANERA

TEM - EPA LEVEL II

[illegible]

SAMPLED BY:	FAIRBANKS, W	DATE: 9/14/02
SIGNATURE:	<i>[Signature]</i>	
RELEASED BY:	FAIRBANKS, W	DATE: 9/14/02
SIGNATURE:	<i>[Signature]</i>	
RECEIVED BY:	A. CATTIGAL	DATE: 9/15/02
SIGNATURE:	<i>[Signature]</i>	

SAMPLE TYPE CONES

1 - Blank

2 - Pre-Abatement

3 - Durino Abatement

A - Durlin Glove Ban Remains!

8 - Background

0 - Background

ALPINE VILLAGES

SEE BEVERE GIDEON AMI YIC INFAMIA WAA