

Address: 115 Broadway

INCLUDES RESULTS
PERTAINING TO
"MEN'S SUIT STORE"
IN BLOG

Bulk Samples
PLM

Yes

No

Number of Negative ($\leq 1\%$) Samples

4

Number of Positive ($> 1\%$) Samples

19

NOTE: ADDITIONAL LAB
RESULTS ARE CONTAINED
IN REPORT

Air Samples

Yes

No

PCM

Number of Samples Collected ($\leq 0.01 \text{ f/cc}$)

608

Number of Samples Collected ($> 0.01 \text{ f/cc}$)

41

TEM

Number of Samples Collected ($\leq 70 \text{ s/mm}^2$)

30

Number of Samples Collected ($> 70 \text{ s/mm}^2$)

0

INTERIOR DEBRIS - INDICATED THAT DEBRIS PRESENT
(See II, p2) (Sec. II, Scope of Work)

GENERAL CLEAN-UP - INDICATED THAT CLEANING DONE
(See Sec. 2, p1 et al.)

ACM CLEANUP - INDICATED THAT LIC'D ASBESTOS CONTRACT-
OR 2nd WORK (VACUUMING ETC) PROJECT "FILED"
W/NO DEP. (ACP 7). *SEE REPORT FOR FURTHER DETAILS*

Address: 111 BROOKWAY

~~REPORT IS FOR~~

Bulk Samples
PLM

Yes

No

Number of Negative ($\leq 1\%$) Samples

20

Number of Positive ($> 1\%$) Samples

3

Air Samples

Yes

No

NOTE: DUPLICATIVE LAB
RESULTS ARE CONTAINED
IN REPORT

PCM

Number of Samples Collected (≤ 0.01 f/cc)

560

Number of Samples Collected (> 0.01 f/cc)

7

TEM

Number of Samples Collected (≤ 70 s/mm²)

7

Number of Samples Collected (> 70 s/mm²)

0

INTERIOR DEBRIS - INDICATED THAT DEBRIS PRESENT
(SEE SEC. 1.2.2)

GENERAL CLEAN-UP - INDICATED THAT CLEANING DONE
(SEE SEC. 1.2.1 & 1.2.2)

ACM CLEANUP - INDICATED THAT WORK DONE BY
LICENSED ASB. CONTRACTOR (SEE SEC. 1.2.2)

* SEE REPORT FOR FURTHER DETAILS *