

Aug 17 04 02:21p

IBM USER

732 6018

p.3

RJ Lee Group, Inc. 100 Mr. Hoover Drive

Date: 8/12/2004 Time: 11:10:40 AM

Page 2 of 4

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146Report Date: 8/12/2004
Sample Receipt Date: 8/11/2004
RJ Lee Group Job No.: ATH306300-988
Samples Received: 9
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
		Start	Stop								Analytical Sensitivity (S/mm ²)	(S/cc)
228922.HT	Field Blank	8/9/2004	8/9/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	0.000	0.08949	0 0	< 11.2 11.2	N/A N/A
228923.HT	Area	8/9/2004	8/9/2004	99	Not Acquired	(SouthWest) - Washington and Albany	335	1860.00	0.04475	0 0	< 22.3 22.3	< 0.005 0.005
228924.HT	Area	8/9/2004	8/9/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	335	1848.00	0.04475	1 0	22.3 22.3	0.005 0.005
228926.HT	Area	8/9/2004	8/9/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	1792.00	0.04475	0 0	< 22.3 22.3	< 0.005 0.005
228944.HT	Field Blank	8/9/2004	8/9/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	0.000	0.08949	0 0	< 11.2 11.2	N/A N/A
228945.HT	Area	8/9/2004	8/10/2004	99	Not Acquired	(SouthWest) - Washington and Albany	335	2016.00	0.04475	0 0	< 22.3 22.3	< 0.004 0.004
228946.HT	Area	8/9/2004	8/10/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	335	2016.00	0.04475	0 0	< 22.3 22.3	< 0.004 0.004
228947.HT	Area	8/9/2004	8/10/2004	99	N/A	(East) - Greenwich	335	2012.00	0.04475	0 0	< 22.3 22.3	< 0.004 0.004
228948.HT	Area	8/9/2004	8/10/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	2008.00	0.04475	0 0	< 22.3 22.3	< 0.004 0.004

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.

2. "-" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.

3. Samples for this project were analyzed at our Monroeville, PA (NYLAP #101208-0, NY ELAP #10844) facility.

4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.

Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.

5. Samples will be held for 90 days and then disposed of per Federal regulations.

6. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Aug 17 04 02:21p

IBM USER

732 6018

p.2

RJ Lee Group, Inc. 100 River Orange

Date: 8/17/2004 Time: 8:02:16 AM

Page 2 of 3

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 8/11/2004
Sample Receipt Date: 8/10/2004
RJ Lee Group Job No.: ATH306366-981
Samples Received: 4
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
		Start	Stop								Analytical Sensitivity (S/mm ²)	(S/cc)
228933.HT	Field Blank	8/9/2004	8/9/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	0.000	0.08932	0 0	< 11.2 11.2	N/A N/A
228934.HT	Area	8/9/2004	8/9/2004	99	Not Acquired	(SouthWest) - Washington and Albany	335	1884.00	0.04466	0 0	< 22.4 22.4	< 0.005 0.005
228935.HT	Area	8/9/2004	8/9/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	335	1584.00	0.05359	0 0	< 18.7 18.7	< 0.005 0.005
228936.HT	Area	8/9/2004	8/9/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	1970.00	0.04466	0 0	< 22.4 22.4	< 0.004 0.004

Authorized Signature: _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- Indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Samples for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.