

Aug 17 04 02:26p

IBM USER

732 6018

p.3

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
NA

Report Date: 8/13/2004
Sample Receipt Date: 8/12/2004
RJ Lee Group Job No. ATH306306-992
Samples Received: 5
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
23005.HT	Field Blank	8/11/2004 8/11/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	0.000	0.08949	0 0	< 11.2 11.2	N/A N/A
23006.HT	Area	8/11/2004 8/11/2004	99	Not Acquired	(SouthWest) - Washington and Albany	335	1840.00	0.04475	0 0	< 22.3 22.3	< 0.005 0.005
23007.HT	Area	8/11/2004 8/11/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	335	1864.00	0.04475	0 0	< 22.3 22.3	< 0.005 0.005
23008.HT	Area	8/11/2004 8/11/2004	99	N/A	(East) - Greenwich	335	1820.00	0.04475	0 0	< 22.3 22.3	< 0.005 0.005
23009.HT	Area	8/11/2004 8/11/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	1892.00	0.04475	0 0	< 22.3 22.3	< 0.005 0.005

Authorized Signature: _____

Kimberly A. Allison, Manager - TEM Analysis

/s/b

Notes

Volumes provided by Ambient were used to calculate analytical results and sensitivities.

"<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.

Samples for this project were analyzed at our Monroeville, PA (NVLAP #101368-0, NY ELAP #10844) facility.

If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.

Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.

Samples will be held for 90 days and then disposed of per Federal regulations.

These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Aug 17 04 02:26p IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
Date: 8/14/2004 Time: 11:59:28 AM

P. 4
Page 6 of 8

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 8/14/2004
Sample Receipt Date: 8/13/2004
RJ Lee Group Job No.: ATH366366-994
Samples Received: 10
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity	
										(S/mm)	(S/cc)
228728.HT	Field Blank	8/11/2004 8/11/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08949	0 0	< 11.2 11.2	N/A N/A
228729.HT	Area	8/11/2004 8/12/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2008.00	0.04475	0 0	< 22.3 22.3	< 0.004 0.004
228730.HT	Area	8/11/2004 8/12/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	335	2119.25	0.04475	0 0	22.3 22.3	< 0.004 0.004
228731.HT	Area	8/11/2004 8/12/2004	99	N/A	(East) - Greenwich	385	2000.00	0.04475	0 0	< 22.3 22.3	< 0.004 0.004
228732.HT	Area	8/11/2004 8/12/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2008.00	0.04475	0 0	< 22.3 22.3	< 0.004 0.004
228761.HT	Field Blank	8/11/2004 8/11/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	0.000	0.08949	0 0	< 11.2 11.2	N/A N/A
228762.HT	Area	8/11/2004 8/11/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1920.00	0.04475	0 0	< 22.3 22.3	< 0.004 0.004
228763.HT	Area	8/11/2004 8/11/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1896.00	0.04475	0 0	< 22.3 22.3	< 0.005 0.005
228764.HT	Area	8/11/2004 8/11/2004	99	N/A	(East) - Greenwich	385	1880.00	0.04475	0 0	< 22.3 22.3	< 0.005 0.005
228765.HT	Area	8/11/2004 8/11/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1864.00	0.04475	0 0	< 22.3 22.3	< 0.005 0.005

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "-" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
3. Samples for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Aug 17 04 02:27p IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
Date: 8/14/2004 Time: 11:59:26 AM

P. 5
Page 7 of 8

RJ Lee Group, Inc.

Laboratory Report (cont.)

Lee Group Job No: ATH306366-994
Building: 130 Liberty

RJ Lee Group, Inc.
Report Date: 8/14/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)

Authorized Signature: _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

* Values provided by Ambient were used to calculate analytical results and sensitivities.

* Indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.

* Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility

If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.

* Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.

* Samples will be held for 90 days and then disposed of per Federal regulations.

* These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.