

Aug 17 04 02:15p

IBM USER

732 6018

p. 2

RJ Lee Group, Inc. 10. Mr. Noel Drago

Date: 8/10/2004 Time: 10:37:22 AM

Page 2 of 3

8/7

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 8/10/2004
Sample Receipt Date: 8/9/2004
RJ Lee Group Job No.: ATH306366-979
Samples Received: 0
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
		Start	Stop								Analytical Sensitivity (S/mm ²)	(S/cc)
5226595.HT	Area	8/7/2004	8/7/2004	99	Not Acquired	(SouthWest) - Washington and Albany	335	1912.00	0.04466	0 0	< 22.4 22.4	< 0.005 0.005
5226594.HT	Field Blank	8/7/2004	8/7/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08932	0 0	< 11.2 11.2	N/A N/A
5226596.HT	Area	8/7/2004	8/7/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	335	1916.00	0.04466	0 0	< 22.4 22.4	< 0.004 0.004
5226597.HT	Area	8/7/2004	8/7/2004	99	N/A	(East) - Greenwich	335	1924.00	0.04466	0 0	< 22.4 22.4	< 0.004 0.004
5226598.HT	Area	8/7/2004	8/7/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	1926.00	0.04466	0 0	< 22.4 22.4	< 0.004 0.004

Authorized Signature. _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes

- 1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- 2. "..." indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
- 3. Samples for this project were analyzed at our Monroeville, PA (NVLAP #161208-0, NY ELAP #16844) facility.
- 4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- 5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- 6. Samples will be held for 90 days and then disposed of per Federal regulations.
- 7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Aug 17 04 02:16p

IBM USER

732 6018

p.3

RJ Lee Group, Inc. 101 NW Noel Drive

Date: 8/11/2004 Time 9:14:28 AM

Page 2 of 4

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 8/11/2004
Sample Receipt Date: 8/10/2004
RJ Lee Group Job No.: ATH306306-983
Samples Received: 10
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)
226047.HT	Field Blank	8/7/2004	8/7/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	0.000	0.08932	0	0	< 11.2 11.2	N/A N/A
226048.HT	Area	8/7/2004	8/7/2004	99	Not Acquired	(SouthWest) - Washington and Albany	335	1920.00	0.04466	0	0	< 22.4 22.4	< 0.004 0.004
522650.HT	Area	8/7/2004	8/7/2004	99	N/A	(East) - Greenwich	335	1912.00	0.04466	0	0	< 22.4 22.4	< 0.005 0.005
226049.HT	Area	8/7/2004	8/7/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	335	1916.00	0.04466	0	0	< 22.4 22.4	< 0.004 0.004
226874.HT	Field Blank	8/7/2004	8/7/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	0.000	0.08932	0	0	< 11.2 11.2	N/A N/A
226651.HT	Area	8/7/2004	8/7/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	1896.00	0.04466	0	0	< 22.4 22.4	< 0.005 0.005
226875.HT	Area	8/7/2004	8/8/2004	99	Not Acquired	(SouthWest) - Washington and Albany	335	1800.00	0.04466	0	0	< 22.4 22.4	< 0.005 0.005
5228877.HT	Area	8/7/2004	8/8/2004	99	N/A	(East) - Greenwich	335	1912.00	0.04466	0	0	< 22.4 22.4	< 0.005 0.005
226876.HT	Area	8/7/2004	8/8/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	335	1916.00	0.04466	0	0	< 22.4 22.4	< 0.004 0.004
5228878.HT	Area	8/7/2004	8/8/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	1792.50	0.04466	0	0	< 22.4 22.4	< 0.005 0.005

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "-" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
- Samples for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Aug 17 04 02:16p IBM USER
From: RJ Lee Group Inc To: Mr. Noe Drago

732 6018
Date: 8/11/2004 Time: 9:14:28 AM

P. 4
Page 3 of 4

RJ Lee Group, Inc.

Laboratory Report (cont.)

RJ Lee Group Job No: ATH306366-983
Building: 130 Liberty

RJ Lee Group, Inc.
Report Date: 8/11/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)

Authorized Signature: _____

 /s/ Kimberly A. Allison, Manager - TEM Analysis

Notes

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "-" indicates results less than analytical sensitivity. "----" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.