

Aug 17 04 02:11p

IBM USER

732 6018

p. 1

RJ LeeGroup, Inc.

8/5

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799**Final Laboratory Report**
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
PAReport Date: 8/6/2004
Sample Receipt Date: 8/6/2004
RJ Lee Group Job No.: ATH300360-965
Samples Received: 5
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
26583 HT	Field Blank	8/5/2004	8/5/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	0.000	0.08839	0	0	< 11.3 11.3	N/A N/A
26584 HT	Area	8/5/2004	8/5/2004	99	Not Acquired	(SouthWest) - Washington and Albany	335	1816.00	0.04420	0	0	< 22.6 22.6	< 0.005 0.005
26585 HT	Area	8/5/2004	8/5/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	335	1830.00	0.04420	0	0	< 22.6 22.6	< 0.005 0.005
26586 HT	Area	8/5/2004	8/5/2004	99	N/A	(East) - Greenwich	335	1852.00	0.04420	0	0	< 22.6 22.6	< 0.005 0.005
26587 HT	Area	8/5/2004	8/5/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	1876.00	0.04420	0	0	< 22.6 22.6	< 0.005 0.005

Authorized Signature: _____

/s/lb

Kimberly A. Allison, Manager - TEM Analysis

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
- Samples for this project were analyzed at our Monroeville, PA (NVLAP #101308-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 333-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 8/9/2004
Sample Receipt Date: 8/8/2004
RJ Lee Group Job No.: ATH300306-970
Samples Received: 10
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity	
										(S/mm ²)	(S/cc)
7229120.HT	Field Blank	8/5/2004 8/5/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08932	0 0	11.2 11.2	N/A N/A
7229121.HT	Area	8/5/2004 8/5/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2024.00	0.04466	0 0	< 22.4 22.4	< 0.004 0.004
7229122.HT	Area	8/5/2004 8/5/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2012.00	0.04466	0 0	< 22.4 22.4	< 0.004 0.004
7229123.HT	Area	8/5/2004 8/5/2004	99	N/A	(East) - Greenwich	385	2008.00	0.04466	0 0	< 22.4 22.4	< 0.004 0.004
7229124.HT	Area	8/5/2004 8/5/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1984.00	0.04466	0 0	< 22.4 22.4	< 0.004 0.004
7229131.HT	Field Blank	8/5/2004 8/5/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08932	0 0	11.2 11.2	N/A N/A
7229132.HT	Area	8/5/2004 8/6/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1924.00	0.04466	0 0	< 22.4 22.4	< 0.004 0.004
7229133.HT	Area	8/5/2004 8/6/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1924.00	0.04466	0 0	< 22.4 22.4	< 0.004 0.004
7229134.HT	Area	8/5/2004 8/6/2004	99	N/A	(East) - Greenwich	385	1916.00	0.04466	0 0	< 22.4 22.4	< 0.004 0.004
7229135.HT	Area	8/5/2004 8/6/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1912.00	0.04466	0 0	< 22.4 22.4	< 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
- Samples for this project were analyzed at our Monroeville, PA (NYLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Aug 17 04 02:11p

IBM USER

732 6018

p.3


RJ Lee Group, Inc.**Laboratory Report (cont.)**

Lee Group Job No: ATH306366-970
Building: 130 Liberty

RJ Lee Group, Inc
Report Date: 8/9/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (nm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start Stop								Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)

Authorized Signature: _____

 /sib
Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "..." indicates results less than analytical sensitivity. "..." indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.